

**PR NO. 317354**  
**RFQ NO. 43510**

**TENDER NOTICE NO.: 03 /2017-2018**

**Name of Work: Open tender for Erection work of HT, LT & T/C line at Suigam (Part-1) Sub-division under Radhanpur Division Office.**

Estimate cost.	Rs. 10,00,000.00
Earnest Money.	Rs. 10,000.00 in form of Demand Draft of nationalized bank
Security Deposit.	5% of Order value
Last date of download of tender from online	Date: 14-06-2017 On 15.00 Hrs.
Last Date of document received	Date: 15-06-2017 On 15.00 Hrs. (By RPAD)
Date of opening the tender at	Date: 16-06-2017 On 15.00 Hrs. (If Possible )
Type of tender	Open
Tender Fee	Rs. 1000.00 Receipt No: _____ & Date: _____
Time Limit.	12 month

Tender fee & Earnest money deposit will be accepted in cash or by demand draft on any schedule bank at Radhanpur in favors of "UTTAR GUJARAT VIJ COMPANY LIMITED", cheques or Bank guarantee will not be accepted.

NOTE: This is online tender and put at www.nprocure.com site so fill on line and must send tender through RPAD. Tender received through RPAD only will be accepted.

**SUPDT.ACCTT. (Exp)**  
**UGVCL,DO Radhanpur**

**EXECUTIVE ENGINEER**  
**UGVCL, DO Radhanpur**

To be filed in the Tender.

- (1) Tendered Value :  
(To be filed by the Contractor) Rs. \_\_\_\_\_
- (2) Earnest Money Deposit  
Paid vide DD No. \_\_\_\_\_ Date \_\_\_\_\_ Rs \_\_\_\_\_
- (3) Sales Tax No. \_\_\_\_\_  
Date:- \_\_\_\_\_

**SCHEDULE: “B”**

**Name of Work:** Open tender for Erection work of HT, LT & T/C line at **Suigam (Part-1)** Sub-division under **Radhanpur** Division Office.

Sr. No	Description of works	Qty	Unit	Tendered rate		Total Amount
				In figure	In Words	
1	2	3	4	5	6	7
1 (a)	Tapping from existing pole including fitting of clamps cross arms insulators & painting of iron parts as per drawing & specification for HT line	80	Nos	278	Rupees Two Hundred Seventy Eight Only	22240.00
1 (b)	LT Tapping from Existing LT Line-Single Phase	50	Nos	31	Rupees Thirty One Only	1550.00
	LT Tapping from Existing LT Line-three Phase					
2	Erection of HT Line single pole structure comprising of excavation of pit and refilling of earth with cast iron base plates with top Insulators, Cross arm etc. complete as per drawing and specification with painting numbering and fixing of caution board and std. anticlimbing devices + for single pole structure. The rates are inclusive of paint, but nut bolt, Barbered wire and caution board will be supplied by the company.					
	(A) PSC pole 8 Mtr. Long 140 Kg./200 Kg.	200	Nos	675	Rupees Six Hundred Seventy Five Only	135000.00
	(B) Steel pole 40 to 90 lbs 30 to 42 feet	5	Nos	1315	Rupees One Thousand Three Hundred Fifteen Only	6575.00
	(C) PSC pole 10 MT long 270 Kg.	5	Nos	1815	Rupees One Thousand Eight Hundred Fifteen Only	9075.00
3	Erection of special two pole structure such as tapping Railway crossing structure and river crossing and structure for strain point with base plate X-arm, cross bracing etc. complete as per drawing and specification with painting numbering fixing of caution board and					

	std. anticlimbing device including supply of paint, Nuts, Bolts, and 2 Kg. Barbed wire of approved quality by the contractor.					
	(a) PSC pole 8 Mtr. Long with DO unit PSC Steel pole	3	Nos	1650	Rupees One Thousand Six hundred Fifty Only	4950.00
	Stringing of ACSR and all aluminium conductor with Insulator binding, Jumpering and joining etc. as per specification and drawing					
4	(A) Stringing of conductor 13mm <sup>2</sup> size to 55mm <sup>2</sup> size for HT & LT line	120	Kms	1240	Rupees One Thousand Two Hundred Forty Only	148800.00
5	Conversion of LT line to HT line i.e. removing of LT line, conductor, LT shackle, LT shackle Bolt, U-clamp etc. And crediting removed materials to Store and providing HT line material i.e. HT conductor, V-Cross arm, Pin insulator, GI pin, etc.	6	Kms	6930	Rupees Six Thousand Nine Hundred Thirty Only	41580.00
6	Erection of stay set complete as per drawing and specification with stay clamps, stay wire, Turn buckle, Guy insulators and cement blocks including supply of Bolts & Nuts by the contractor.	380	Nos	315	Rupees Three Hundred Fifteen Only	119700.00
7	(A) Erection of guarding with cross arms, bolts wire etc. complete as per specification for HT/LT line.	600	Rmt.	58	Rupees Fifty Eight Only	34800.00
8	Reactivation of old earthing coil type or CI plate type including cost of Charcoal, Salt etc. but without cost of GI wire and earthing plate as per standard specification	50	NOS	330	Rupees Three Hundred Fifty Only	16500.00
9	Erection of transformer centre completely excluding guy & earthing for for 100 KVA transformer using PSC poles	65	Nos	5360	Rupees Five Thousand Three Hundred sixty Only	348400.00
10	Erection of transformer centre completely excluding guy & earthing for for 100 KVA transformer using RSJ 9 mtr poles	3	Nos.	6160	Rupees Six Thousand One Hundred sixty Only	18480.00
11	Concreting of pole including cost of cement, sand, metal(1:3:6) & water as per STD specification	6	Cubm c mtr	5900	Rupees Five Thousand Nine Hundred Only	35400.00
12	Removal of deteriorated PSC poles and crediting to store.	40	NOS	465	Rupees Four Hundred Sixty Five Only	18600.00
13	Dismantling of existing transformer centre including of fabrication with poles and credited to store for PSC poles & erection.	5	NOS	1870	Rupees One Thousand Eight Hundred Seventeen Only	9350.00

Save Energy for Benefit of Self and Nation



14	Dismantling of existing transformer centre including of fabrication with poles and credited to store for RSJ poles & erection.	2	NOS	2750	Rupees Two Thousand Seven Hundred Fifty Only	5500.00
15	Dismantling of existing T/c. & erection of same T/c. with replacement of poles with fitting of all materials with painting including nut, bolts excluding guy & earthing of required new Guy & earthing at the rate of maintenance work.	2	NOS	7230	Rupees Seven Thousand Two Hundred Thirty Only	14460.00
16	Dismantling of existing conductor of difference size upto 55mm <sup>2</sup> with cross arm and top fitting including everything	6	KMs.	620	Rupees Six Hundred Twenty Only	3720.00
					Total B	<b>994680.00</b>
<b>Nine Lacs Ninety Four Thousand Six Hundred Eighty Only.</b>						

**Note:- The rates are exclusive of nut bolt, Barbed Wire and caution Board. The UGVCL will supply the required nut-bolts, Barbed Wire and caution Board.**

The rates quoted are \_\_\_\_% above/below to the scheduled rates as shown in SCHEDULE -B above.

Note: - Work to be carried out as per site situation & instruction of Engineer In charge.

**Executive Engineer  
UGVCL, DO Radhanpur**

Contractor's signature with seal.

Date: \_\_\_\_\_

---

**Regd. & Corporate Office: Visnagar Road, MEHSANA - 384 001 (North Gujarat)**

Telephone: (02762) 222080-81

Website: www.ugvcl.com

Fax: (02762) 223574

e-mail: corporate@ugvcl.com

## **SPECIFICATIONS:**

For erection work of 11KV/22KV H.T. transmission lines, LT Distribution lines and transformer sub-stations

1. Erection of H.T.lines:

(a) Site clearing and tree cutting will be done by the contractor at his cost. The company will assist the contractor in getting necessary permission for tree cutting etc. Any claim for compensation in above respects will have to be born by the contractor.

(b) Fixing of positions:

The position of poles structure guys and earthings will be fixed by the department and shown to the contractor. He should adhere to these locations in all circumstances unless directed by the department to make any change.

(c) Pole setting:

Where poles are set in good solid ground the depth of pit shall be 1/6th height of the pole and for grounds of any other nature depth of pit shall be decided by the Department. The poles and guys must not be set at the edge of cuts or embankments where the soil is liable to be washed or eroded out. Such settings should be avoided. While back filling the earth must be packed tight and in no case must earth be dumped of a greater depth than our inches without being rammed hard before the next layer is thrown in. The cost of damage done to the pole during erection will be recoverable from the contractor no pole which is out of plumb shall be accepted for recording the measurement for work carried out. The poles once handed over to the contractor will be in his safe custody till erected and he is liable compensate to the company the full cost of pole along with supervisor changes if the pole is broken during erection, or stolen from his custody. He should be able to render full amount of the poles entrusted to him whenever the supervising officer demand to scrutinize the same.

(d) Erection of complete single structure:

Erection of single pole structure comprises of excavations of pit and refilling of earth, erection in position of 28 to 33 PSC pole, 60 lbs/ yds to 90 lbs/yd/30 to 42 long rail or suitable size girder or any other suitable pole, fitting of clamps and cross arms, fitting of insulators etc. complete as per drawing, inclusive of painting numbering fixing of caution board ant climbing device.

(e) Special two pole structure such as for HT line tapping railway crossing any other HT LT or telephone line crossing terminal, structure, structure for transformer sub-station comprises of excavation of suitable pits and refilling of earth erection in position of two Nos. 28 to 33 PSC poles 90-lbs/yd to 90 lbs/yd 30 to 42 long rails of any other suitable poles fitting of clamps and cross arms, bracing cross bracing etc. as per drawing exclusive of mounting transformer but inclusive of mounting D.O. fuses painting numbering fixing of caution Board and anti-climbing device. The D.P. must be in plum. Special structure of included will be erected as per drawing supplied.

(f) Stringing of conductors:

This includes stringing of stranded and solid bare conductors with fitting of necessary HT & LT pin and strain insulators; binding on insulators jumpering jointing, the jointing in HT line will be done by twisting sleeve joints as per standard practice, care must be taken in handling the conductor to protect against cuts, Scratches or kinks. The conductor must not be drawn over rough or rocky ground when it is liable to be danged Aluminum and ACSR conductors must be drawn on wooden or Alum. Pulleys only. The white conductor or coil must not be dropped wastage and cutting should be avoided as far as possible .Not more than 5% scrap will be accepted in the material account to be submitted by the contractor. It is important that the conductor must be drawn to the proper tension. The sag and spans will be maintained as per drawing and design. The cross arm and

insulators must be so fixed that neither tilts or bends in position. The span and sag however may vary according, to sizes of poles available but these dimensions will not be specified by the field Engineer before Commencement of work. The sagging should be uniform for all conductors and uneven sagging will not be allowed. Stringing of V.I.R. line. This consists of VIR wire of different sizes such 3/20 to 7/16 complete with G.I. bearer wire and reel insulators interspaced at a distance of 3 ft.

- (g) **Erection of stay set:**  
The erection of stay set comprises of excavation of suitable pit of 4 depth burying stay rods anchor plate fixing of stay clamp on pole fixing of turn buckle, binding of G.I. stay wire. The stay insulators must be inserted in the stay wire on all stays as per drawing. The wrapping of the guy wire strands at both ends and at stay insulator must be even and must be present neat appearance and good workmanship. No stay should be left loose but should be tight and straight to withstand any cyclone or sand storm.
- (h) **Earthing:**  
The arrangement shall be of pipe type earthing as indicated in the drawing. The earthings are to be done at places as indicated in the pole schedule or as selected by the field Engineer. The coke and salt will have to be supplied by the contractor at his cost. Size of pit 2"x2"x6" Mixture of salt and coal dust 5kg. Each total 10kg.
- (i) **Guarding:**  
The guarding will have to be provided between crossing of HT and LT lines below all the railway crossings at the crossings of telephone or telegraph lines and such of places as indicated by the department. The work comprises of fixing of guard, cross arms, eye bolt, and guard cradle as per design, GI cross lacing wires complete / any special type of guarding if required will be designed and erected by the department. Bridling cross arms must be used where the HT line crosses the road, a clearance of 20' must be available for all Road crossings. The poles for road crossings must be contracted.
- (j) **Painting and numbering:**  
Rail poles and girder poles shall be given one coat of approved red lead paint and two coats of approved allu. Paint. All steel mounting also painted in a manner shown above. The bolts and nuts shall be dipped in anti corrosive oil before insertion. The lower position of steel poles up to 3 feet above ground level shall be cleaned of all dust. This surface should be given a base coat red lead and an additional coat of block bituminous paint before inserting in the ground The paints will be supplied by the contractor and should be Jenson Nicholson or Asian Paints or such other well-known make and will be got approved from Executive Engineer prior to starting work. All poles should be numbered in block figures of 3" size with good paints. The paint for numbering should be of weather proof type and got approved in advance.
- (k) **Concreting:**  
Brickbat Cement Concreting: Cement concrete for concreting of poles and stay rods should be one part cement, three parts of specified quality sand and six parts of burnt brick bats (1:3:6) The concreting should be done on all strain angle, deal end D.P. Structure, Road and Telephone crossings and as directed on other locations.
- (l) **Muffling:**  
Concrete for Muffling of poles and stay rods should be cement one part sand three parts and six parts metal (1:3:6) muffling is not to be done for PSC poles. Sand shall be clean and composed of hard siliceous grains. It shall be free from clay or organic matter. Metal should be of sound hard and durable stone size 1/2" to 3/4" sieve.

(m) Mixing of concrete:

Unless otherwise specified the concrete shall be in above proportion and should be thoroughly mixed at least three times in dry state before water is added and as far as possible a fairly wet mixture must be used. All concrete must be mixed on water tight platform. In any case, the work when finished must be absolutely true inline and level and finished off smooth .One finishing coat, of cement plaster should be applied on outer surface of the muffling, the concrete block when slightly dried should be kept wet continuously for period of 10 days. The locations for concreting will be decided by the Engineer in charge and the contractor will follow his instructions scrupulously. If the concreting work is not found as per the specification and quality, the same is liable to be rejected. The brick bat concreting or cement concreting work has to be done. In the presence of company representative only and work done in his absence will be rejected and no payment made therefore. The contractor will be supplied cement by the department and the cost of the cement will be recovered from the contractor at the rate of Rs. \_\_ per metric ton. All the empty bags will have to be returned to department in good condition otherwise a recovery of Rs.1.00 per bag will be made. The sand, metal brick bats shall be supplied by the contractor. The normal size of concreting of pole will be 5" x2'x2 ½' that for stay 2x2x2' Muffling for poles shall be 12" dia 2"-0" (1' above and 1' below ground ) Muffling for stay shall be 12" dia x 2".0' (1' above and 1' below ground ) The concreting and muffling shall be carried out by the contractor in presence of field Engineer or his representative to ensure that correct quantities are used.

2. TRANSFORMER CENTRE:

The transformer centre will be of out door type on two pole structure as per standard drawing and comprises of:

1. One set of H.T.D.O. fuses.
2. 11/22 KV 25 to 1000 KVA transformer complete with its accessories.
3. One set of HT lightening arrestors.
4. One set of LT lightening arrestors.
5. One dist Box pipes, VIR wires, cross arms and bracings earthing as per drawing etc.
6. Stays with insulators, painting numbering dangers board, anti-climbing device. The independent separate pipe type earthings should be provided on either side of the T/C each consisting of one or more earth connections from lightening arrestor's transformer neutral transformer tank dist. Box etc. The cost of damage done to the transformer is recoverable from contractor.

*Save Energy for Benefit of Self and Nation*



**GENERAL:**

The work should be strictly as per specifications and approved designs of the company. The inferior and unsatisfactory work is liable to be rejected. The detailed specifications and structural drawings can be supplied for reference at the request of contractor. The work will have to be carried out as per programmed laid down by department and under the entire instruction of field engineers and contractor should employ supervisor who could supervise the works throughout and he should remain present on site. No tools will be supplied by the department. The work is found inferior and not up to standards of the company is liable to be rejected at the risk and cost of the contractor. Any expenditure incurred for rectification work carried out departmentally or by employing harmony labour will be recovered from his R.A. Bills of the contractor of the contractor fails to rectify the inferior work done by him insists of instructions to rectify the same. Contractor will have to submit the certificate work of the 2nd class wireman under whose supervision the work has been carried out.

**IMPORTANT:**

Before starting the work (new, alteration or addition) and during the works the contractor must obtain line clear wherever necessary for the concerned officer of this department or other department. For any damage done to the men, materials or property due to non observance of rules, the responsibility will be of the contractor.

**SIGNATURE OF THE CONTRACTOR.**

**Date:** \_\_\_\_\_



**GENERAL INSTRUCTION TO TENDERERS**

- 1 Sealed Tenders are invited for the work of erection of HT/LT line & T/c. at **Suigam (Part-1)** S/Dn offices under division office Radhanpur from the contractors/firms who have executed works of similar nature and magnitude successfully and who are registered under appropriate class.
- 2 Tender documents are in two bids system i.e. “Technical Bid” and “Price Bid”.
  - A. Technical bid is to be submitted in a separate sealed envelope and super scribing the envelope as “Technical Bid”. Technical bid should be submitted with documents as under, failing which tender is liable for rejection.
  - B. Solvency certificate issued from any Nationalized Bank amounting to sum equivalent of estimated cost (Minimum 10.0 Lacs)
  - C. Separate EPF code No. allotted by RPFC & Last Six month of current year EPF Challan paid copy is required.
  - D. Latest income tax clearance certificate.
  - E. **Service tax registration number.**
  - F. **Vendor registration from Corporate Office as per Class-B & A only.**
  - G. Group Insurance copy of the insurance policy of the insured laborer’s under W.C. Act.
  - H. Experience certificate as per requirement for erection of HT-LT line & T/C work by authorized officer of Distribution Company more than 10 lacks in any last three financial years.
  - I. Details of equipments available with the tendered.
  - J. Electrical contractor license as a when required.
  - K. Tools & tackle Certificate.
  - L. At least Rs. 10 Lacs turn over required in bank Statement.
  - M. Proof regarding payment of Tender Fee and EMD. The above supplementary documents should be submitted in form of attested true copies.
  - N. Note: the rates are exclusive of nut bolt.
- 2.2 The Price bid (schedule-B) should be submitted online only and not to submit price bid physically form. This is mandatory if price bids submitted in physically form same will not be open and only online submitted price bid will be considered for evaluation.
- 2.3 Both “Technical” and” EMD Receipt No. should be submitted in one common envelope super scribing the name of the work and tender opening date etc.
- 3 Earnest money deposit of Rs. 10000 should be deposited in cash or submitted in form of Demand Draft in favor of UTTAR GUJARAT VIJ COMPANY LIMITED drawn on any scheduled Bank, payable at **Radhanpur**
- 4 Bidders should complete the tender documents in all respects and they are to be signed with Company’s Seal on all pages.
- 5 The bidders shall submit their offer without any deviations in general terms and conditions of the

- contract or in Technical specification/items. Tenders of such departing may also be rejected. Incomplete and conditional tenders shall not be considered.
- 6 UTTAR GUJARAT VIJ COM.LTD. Reserves the right to split up the work covered in the scope of this contract amongst more than one contractor.
  - 7 The rates shall be quoted both in words and figures as per unit specified in schedule-‘B’ and it should be sticker by the transparent cello tape. In case of any discrepancy between the rates quoted in words & figures, rate quoted in words will prevail.
  - 8 Intending bidders should submit their tenders after studying all tenders documents carefully and visiting the site for satisfying themselves of actual site conditions, location and accessibility of site and nature, extent of the work involved etc. Submission of tenders implies that bidders have obtained all necessary.
  - 9 Information and other data required for executing the work. No claim for extra charges on account
  - 10 Of any misunderstanding or otherwise will be allowed.
  - 11 All approaches to the site shall be in the scope of bidders.
  - 12 Bidders will not be allowed to give sub-contract of the works awarded to him for any, reasons what so ever without permission of the Engineer-in charge.
  - 12.1 In the experience certificate, contractor has to furnish the details of similar works executed by him along with the list of equipment, tools and tackles and manpower available with him along with the details of the same, which he intends to deploy on site of the work.
  - 13 After opening of “Technical bid” no revised price bid from any bidders will be accepted.
  - 14 Price quoted shall be firm, till overall completion of the work, under contract and there will not be any price escalation.
  - 15 Date of opening of “Price Bid” will be intimated later on to those Bidders who are qualified in technical bid. “Price bid” of only qualifying bidders on the basis of Technical bid shall only be opened. Price of bidders, who are not qualified technically as per requirement of technical bid shall not be opened.
  - 16 Offers shall be valid for the period of 120 days from the date of opening of price bid. Tenders shall not withdraw tenders during the validity period, failing which their EMD shall be forfeited during the said period of 120 days.
  - 17 Bolts & nuts of appropriate size and quality will be supplied by the **UGVCL Compaly.**
  - 18 Cement will be issued as per Company existing rates.
  - 19 Materials will be issued strictly as per requirement & not in lot
  - 20 Concrete slabs will be supplied from our store.
  - 21 “0.50 “ps. Per cu ft will be paid below the 2 feet or ground level for the rocky soil against the certificate of Dy. Engineer in charge/verification by concern D.E. tech of Radhanpur Division.
  - 22 Due care should be taken while doing the work, If any accident will occurred to your employee/personal while working than it will be your responsibility. Company will not be responsible for payment of any claims due to such accident.
  - 23 Contractor should observe labour laws as per prevailing rules of Govt. of Gujarat.
  - 24 Tree Branches should be trimmed such a way that distance of nearby conductor and trimmed branch must remain 5’ Horizontal and 5’ vertically.
  - 25 Pin binding of Pin Insulator must be with double strand of conductor.
  - 26 Each and every shackle pole must be re jumpered with formation of ‘D’.
  - 27 Old material removed from line (If any) must be credited in Divn. Store.
  - 28 All tools, tackles used in maintenance will be provided by contractor.

*Save Energy for Benefit of Self and Nation*



- 
- 29 Transportation of labour for the work should be done by contractor.
  - 30 If necessary order of one S/Dn. will be transferred to other S/Dn. depending upon requirement of UGVCL.
  - 31 The clearance as per I.E rules must be maintained.
  - 32 For any dispute jurisdiction of legal will be at **Radhanpur**
  - 33 If the Tenderer/Bidder/Contractor would stand lowest while opening of the tender, He will be intimated by the competent authority with separate letter & will have to provide their skilled Labours gang within week time & He would have to report in written through respective SDO. Otherwise Second lowest bidder will be given chance at the rate of lowest-1.
  - 34 The contractor should have to keep permanently skilled Labours gang in respective Sub-Division for each annual order. If Concern SDO will report that Erection Work is delayed due to non-availability of skilled labour , penalty will be deducted a per rules.
  - 35 All the works shall be carried out as per specifications attached with the tender and relevant Indian Standard issued by Bureau Indian Standards. All materials procured should be confirming to relevant Indian Standard issued by Bureau of Indian Standard.
  - 36 Tenders, who do not fulfill all or any of the conditions of the tender of incomplete in any respect, are liable to rejection.
  - 37 UTTAR GUJARAT VIJ COMPANY LTD, reserves the right to reject any or all Tenders without assigning any reason thereof.
  - 38 Income Tax at prevailing Rate will be deducted as per Income tax Act.
  - 39 The rates are inclusive of PF and all other State/Central Government taxes, cess and levies but exclusive of service tax. Service tax prevailing rate, if applicable will be reimbursed by UGVCL on production of Service tax paid Challan.
  - 40 Any Change in rate of Service tax shall be entertained during contractual period of Contract.

**Signature of contractor**  
**With seal**

**Executive Engineer**  
**UGVCL, Radhanpur**