

AMENDMENT-1

Tender Notice No: PLN-CO-24-2017-18

Tender Serial No: 1

Sub:- Consider below Schedule-B instead of previous Schedule-B

**SCHEDULE: B - PRICE BID**

Name of Work: - Tender for providing and fixing of maintenance free electrode earthing as per specification for Deesa-Town S/Dn under Deesa-1 Division for IPDS scheme.

Sr. No	Particulars of Item	Unit	Supply Part			Erection Part			Grand Total (in Rs.)
			Supply Qty.	Rate	Total (in Rs.)	Erection Qty.	Rate	Total (in Rs.)	
1	Supply of "Eco Safe" maintenance free earthing system comprising of 17.2 mm diameter 3 mtr long earthing electrode with 250 microns copper coating + carbon based conductive back fill "Eco Safe" compound (Resistivity of less than 0.1 ohm mtr) and copper coated clamphaving size of 50x6 mm on top of rod. Also be supplied suitable length of earthing GI strip on DTC having size of 25 x 3 mm with termination on rod to transformer neutral.	No	133	6000	798000				997500
2	Erection of Earthing DTC transformers making of 100 mm dia bore for 3 mtr long electrode making and fixing of earth pit chamber with 25 x 3 mm GI strip from electrode to transformer neutral of suitable length with proper clamping and GI strip cover by ISI marked PVC pipe as per drawing.	No				133	1500	199500	
	Total (A)								997500
	Bidder's offer ( +/- ) in % (B)								
	Grand Total C = A +/- (A*B)								
	GST @ 18% ( D = C x 18 % )								
	Grand Total including GST ( E = C + D )								
	Final offer in Rs.								
	Final offer in words Rupees _____								

Superintending Engineer,  
Palanpur, Circle office.

Executive Engineer  
UGVCL, DO DEESA-1.