

Amendment-1

ADVERTISED TENDER –PLN-CO-23/2017-18

Tender serial No: 26

Sub: Consider below Schedule-B(Sr No.-1) instead of previous schedule-B
(Schedule of rates and prices)

Name of work :- Providing and fixing of maintenance free electrode earthing as per specification under Sidhpur R & Unjha R S/dn under Sidhpur division in DDUGJY scheme.

Sr. No.	Item Description	Unit	Supply			Erection			Grand Total Amt. in Rs.
			Qty.	Unit Rate in Rs.	Total Amt. in Rs	Qty	Unit Rate in Rs.	Total Amt. in Rs	
1	2	3	4	5	6	7	8	9	10
1	Supply of "Eco Safe" Maintenance free Earthing system comprising of 17.3 mm dia 3 mtr long earthing electrode of low carbon steel electrode with 250 microns copper coating + carbon based conductive back fill JEF Eco safe compound (Resistivity of less than 0.10 ohm mtr) & copper Clamp including suitable length earthing GI strip on DTC of 25x3 mm with termination on transformer neutral.	NO	66	6000	396000	0	0	0	396000
2	Erection of Earthing DTC Transformers making of 100 mm dia bore ,mtr long making of earth pit and fixing of earth pit chamber with fixing of 25 x3 mm GI strip from electrode to transformer neutral of suitable length with proper clamping	No	0	0	0	66	1500	99000	99000
Grand Total								99000	495000

Here by, I/We/are agreeing to carry out above work at the rates _____% above/below than estimated amount of work contract.

In words _____% above/below.

So, Total Estimated Amount Rs. _____

Rates Above /Below @ _____% Rs. _____

I/We (Contractor) is /are ready to work with total amount of work contract is rs. _____

In words Rs _____

Superintending Engineer
Palanpur, Circle Office.

Executive Engineer
SIDHPUR DO.