



DISCOM Name: ~~UTTRAR~~ GUJARAT VIJ COMPANY LIMITED

GENERAL ARRANGEMENT AND COMPONENTS DRG.
FOR 200Amp., 415 VOLTS KIT-KAT FUSE

DRG. NO.: UGVCL/KIT-KAT/200A/13

SHEET 2 OF 9

NOTE:- WORD 'PGVCL' AND TRADE MARK OF SUPPLIER SHALL BE

1. EMBOSSED BOTH ON FUSE CARRIER AND BASE
2. GENERAL TOLERANCE ± 5% ON LENGTH, WIDTH AND HEIGHT OF THE BODY
3. CENTRE DISTANCE BETWEEN HOLES OF METAL PARTS
UP TO 50 mm - ± 1mm
ABOVE 50 mm - ± 2mm
4. WALL THICKNESS
UP TO 10 mm - ± 1mm
ABOVE 10 mm - ± 1.5mm
5. TOLERANCE ± 5% IN CERAMIC PARTS
6. ALL DIMENSIONS ARE IN mm

[Signature]
Addl. Chief Engineer (Project)
PGVCL, Corp. Office
Rajkot