



**PART X** SIDE VIEW

**NOTE:-**

1. WORD 'PGVCL' AND TRADE MARK OF SUPPLIER SHALL BE EMBOSSED BOTH ON FUSE CARRIER AND BASE
2. GENERAL TOLERANCE  $\pm 5\%$  ON LENGTH, WIDTH AND HEIGHT OF THE BODY
3. CENTRE DISTANCE BETWEEN HOLES OF METAL PARTS  
UP TO 50 mm -  $\pm 1$ mm  
ABOVE 50 mm -  $\pm 2$ mm
4. WALL THICKNESS  
UP TO 10 mm -  $\pm 1$ mm  
ABOVE 10mm -  $\pm 1.5$ mm
5. TOLERANCE  $\pm 5\%$  IN CERAMIC PARTS
6. ALL DIMENSIONS ARE IN mm

DISCOM Name:- **UTTAR GUJARAT VIJ COMPANY LIMITED**

**GENERAL ARRANGEMENT AND COMPONENTS DRG.  
FOR 200Amp, 415 VOLTS KIT-KAT FUSE**

DRG. NO.:- **JGVCL/KIT-KAT/200A/13**

SHEET 4 OF 9

*[Signature]*  
Addl. Chief Engineer (Project)  
**PGVCL, Corp. Office**  
Rajkot