



SIDE VIEW

NOTE:-

1. WORD 'PGVCL' AND TRADE MARK OF SUPPLIER SHALL BE EMBOSSED BOTH ON FUSE CARRIER AND BASE
2. GENERAL TOLERANCE $\pm 5\%$ ON LENGTH, WIDTH AND HEIGHT OF THE BODY
3. CENTRE DISTANCE BETWEEN HOLES OF METAL PARTS
 UP TO 50 mm - ± 1 mm
 ABOVE 50 mm - ± 2 mm
4. WALL THICKNESS
 UP TO 10 mm - ± 1 mm
 ABOVE 10 mm - ± 1.5 mm
5. TOLERANCE $\pm 5\%$ IN CERAMIC PARTS
6. ALL DIMENSIONS ARE IN mm

Addl. Chief Engineer (Project)
 PGVCL, Corp. Office
 Rajkot

DISCOM Name: **UTTAR GUJARAT VIJ COMPANY LIMITED**

GENERAL ARRANGEMENT AND COMPONENTS DRG.
 FOR 200amp, 415 VOLTS KIT-KAT FUSE

DRG. NO.: **JGVCL/KIT-KAT/200A/13**

SHEET 5 OF 9