



TOP VIEW OF CARRIER

DISCOM Name: UTTAR GUJARAT VIJ COMPANY LIMITED	
GENERAL ARRANGEMENT AND COMPONENTS DRG. FOR 200Amp., 415 VOLTS KIT-KAT FUSE	
DRG. NO.: JGVCL/KIT-KAT/200A/13	SHEET 7 OF 9

NOTE:- WORD 'PGVCL' AND TRADE MARK OF SUPPLIER SHALL BE

- EMBOSSED BOTH ON FUSE CARRIER AND BASE
- GENERAL TOLERANCE $\pm 5\%$ ON LENGTH, WIDTH AND HEIGHT OF THE BODY
- CENTRE DISTANCE BETWEEN HOLES OF METAL PARTS
UP TO 50 mm - ± 1 mm
ABOVE 50 mm - ± 2 mm
- WALL THICKNESS
UP TO 10 mm - ± 1 mm
ABOVE 10 mm - ± 1.5 mm
- TOLERANCE $\pm 5\%$ IN CERAMIC PARTS
- ALL DIMENSIONS ARE IN mm

[Signature]
Addl. Chief Engineer (Project)
PGVCL, Corp. Office
Rajkot