



**PART X**

- NOTE:-
- WORD 'PGVCL' AND TRADE MARK OF SUPPLIER SHALL BE EMBOSSED BOTH ON FUSE CARRIER AND BASE
  - GENERAL TOLERANCE  $\pm 5\%$  ON LENGTH, WIDTH AND HEIGHT OF THE BODY
  - CENTRE DISTANCE BETWEEN HOLES OF METAL PARTS  
 UP TO 50 mm.  $\pm 1$ mm  
 ABOVE 50 mm.  $\pm 2$ mm
  - WALL THICKNESS  
 UP TO 10 mm.  $\pm 1$ mm  
 ABOVE 10mm.  $\pm 1.5$ mm
  - TOLERANCE  $\pm 5\%$  IN CERAMIC PARTS
  - ALL DIMENSIONS ARE IN mm

*[Signature]*  
 Addl. Chief Engineer (Project)  
 PGVCL, Corp. Office  
 Rajkot

DISCOM Name:- **UTTA & GUJARAT VIJ COMPANY LIMITED**  
 GENERAL ARRANGEMENT AND COMPONENTS DRG.  
 FOR 200Amp., 415 VOLTS KIT-KAT FUSE

DRG. NO.: **JGVCL/KIT-KAT/200A/13**

SHEET 8 OF 9