



- NOTE:-
1. WORD 'PGVCL' AND TRADE MARK OF SUPPLIER SHALL BE EMBOSSED BOTH ON FUZE CARRIER AND BASE
 2. GENERAL TOLERANCE ± 5% ON LENGTH, WIDTH AND HEIGHT OF THE BODY
 3. CENTRE DISTANCE BETWEEN HOLES OF METAL PARTS
UP TO 50 mm - ± 1mm
ABOVE 50 mm - ±2mm
 4. WALL THICKNESS
UP TO 10 mm - ±1mm
ABOVE 10mm - ±1.5mm
 5. TOLERANCE ± 5% IN CERAMIC PARTS
 6. ALL DIMENSIONS ARE IN mm

[Signature]
 Addl. Chief Engineer (Project)
 PGVCL, Corp. Office
 Rajkot

DISCOM Name:- **UTTA R-GUJARAT VIJ COMPANY LIMITED**

GENERAL ARRANGEMENT AND COMPONENTS DRG. FOR
 200Amp., 415 VOLTS KIT-KAT FUSE

DRG. NO.:- **UGVCL/KIT-KAT/200A/13**

SHEET 9 OF 9