



PART X
SIDE VIEW

NOTE:-

1. WORD \cup GVCL AND TRADE MARK OF SUPPLIER SHALL BE EMBOSSED BOTH ON FUSE CARRIER AND BASE
2. GENERAL TOLERANCE $\pm 5\%$ ON LENGTH, WIDTH AND HEIGHT OF THE BODY
3. CENTRE DISTANCE BETWEEN HOLES OF METAL PARTS
UP TO 50 mm - ± 1 mm
ABOVE 50 mm - ± 2 mm
4. WALL THICKNESS
UP TO 10 mm - ± 1 mm
ABOVE 10 mm - ± 1.5 mm
5. TOLERANCE $\pm 5\%$ IN CERAMIC PARTS
6. ALL DIMENSIONS ARE IN mm

DISCOM Name:- **UTTAR GUJARAT VIJ COMPANY LIMITED**

**GENERAL ARRANGEMENT AND COMPONENTS DRG.
FOR 200Amp., 415 VOLTS KIT-KAT FUSE**

DRG. NO.:- **DISCOM/FUSE /01 REV.02**

SHEET 4 OF 9