



- NOTE:-
1. WORD UGVCL AND TRADE MARK OF SUPPLIER SHALL BE EMBOSSED BOTH ON FUSE CARRIER AND BASE
 2. GENERAL TOLERANCE $\pm 5\%$ ON LENGTH, WIDTH AND HEIGHT OF THE BODY
 3. CENTRE DISTANCE BETWEEN HOLES OF METAL PARTS
 UP TO 50 mm - ± 1 mm
 ABOVE 50 mm - ± 2 mm
 4. WALL THICKNESS
 UP TO 10 mm - ± 1 mm
 ABOVE 10 mm - ± 1.5 mm
 5. TOLERANCE $\pm 5\%$ IN CERAMIC PARTS
 6. ALL DIMENSIONS ARE IN mm

DISCOM Name:- ઉત્તર ગુજરાત વિજ કંપની લિમિટેડ

GENERAL ARRANGEMENT AND COMPONENTS DRG.
 FOR 200Amp, 415 VOLTS KIT-KAT FUSE

DRG. NO.:- DISCOM/FUSE/01 REV.02

SHEET 2 OF 9