



SIDE VIEW

NOTE:-

1. WORD UGVCL AND TRADE MARK OF SUPPLIER SHALL BE EMBOSSED BOTH ON FUSE CARRIER AND BASE
2. GENERAL TOLERANCE ± 5% ON LENGTH, WIDTH AND HEIGHT OF THE BODY
3. CENTRE DISTANCE BETWEEN HOLES OF METAL PARTS
 UP TO 50 mm - ± 1mm
 ABOVE 50 mm - ± 2mm
4. WALL THICKNESS
 UP TO 10 mm - ± 1mm
 ABOVE 10 mm - ± 1.5mm
5. TOLERANCE ± 5% IN CERAMIC PARTS
6. ALL DIMENSIONS ARE IN mm

DISCOM Name:- ઉત્તર ગુજરાત વીજ કંપની લિમિટેડ	
GENERAL ARRANGEMENT AND COMPONENTS DRG. FOR 200Amp., 415 VOLTS KIT-KAT FUSE	
DRG. NO.:- DISCOM / FUSE / 01	REV.02
SHEET 5 OF 9	