



PART X

NOTE:-

1. WORD JGVCL AND TRADE MARK OF SUPPLIER SHALL BE EMBOSSED BOTH ON FUSE CARRIER AND BASE
2. GENERAL TOLERANCE $\pm 5\%$ ON LENGTH, WIDTH AND HEIGHT OF THE BODY
3. CENTRE DISTANCE BETWEEN HOLES OF METAL PARTS
 - UP TO 50 mm - ± 1 mm
 - ABOVE 50 mm - ± 2 mm
4. WALL THICKNESS
 - UP TO 10 mm - ± 1 mm
 - ABOVE 10mm - ± 1.5 mm
5. TOLERANCE $\pm 5\%$ IN CERAMIC PARTS
6. ALL DIMENSIONS ARE IN mm

DISCOM Name:- UTTAR GUJARAT VIJ COMPANY LIMITED

GENERAL ARRANGEMENT AND COMPONENTS DRG.
FOR 200Amp., 415 VOLTS KIT-KAT FUSE

DRG. NO.:- DISCOM /FUSE /01 REV.02

SHEET 8 OF 9