


NOTE: The portions marked ----- shall be unglazed.
SHACKLE INSULATOR

NOTE :-

- | | |
|---|--|
| 1. APPLICABLE STANDARD | IS 1445 / 1977 |
| DESIGNATION | 1 FIG-3 |
| 2. COLOUR OF GLAZE | BROWN |
| 3. SIZE OF INSULATOR | MM 90 X 75 |
| 4. MIN FALLING LOAD | KN 11.5 |
| 5. P.F. WITHSTAND VOLTAGE DRY KV | 28 (gms) |
| 6. P.F. WITHSTAND VOLTAGE WET KV | 10 (fms) |
| 7. V.F. PUNCTURE WITH STAND VOLTAGE WBT | 1.3X The actual dry flesh over voltage |
| 8. MARKING AS PER IS | IS 1445 / 1977
11 5KN |
| 11 ALL DIMENSION ARE | MM
MONTH / YERR |

Chief Engineer (P & P)
 U.G.V.C.L. Office,
 Mansara.



DAKSHIN GUJARAT VII CO. LTD. SURAT.
 DRAWING:
L.T. SHACKLE INSULATOR