

UTTAR GUJARAT VIJ COMPANY LIMITED

TENDER NOTICE No. UGVCL/SP/IV/1150/Rubber Hand Gloves

Specification for Rubber Hand Gloves for Electrical purpose

Sr. No	Particular	Specification
1	Certification	EN 60903 with latest amendments.
2	Class of gloves	Class 1
3	Working Voltage	7.5 KV
4	Test Voltage	10 KV AC
5	Color	Color of Rubber Hand Gloves (Class I - for 11 KV) should be Natural (Ivory) or Any Color.
6	Material	Natural or Synthetic Rubber or combination of both Length: - 360 mm
7	Thickness	1.5 mm
8	Tensile strength	As per above standard
9	Elongation at break percent	As per above standard
10	Puncture resistance	As per above standard
11	Qty/Size	As per requirement
12	Marking on Gloves	1) Markings as per clause No. 5.7 of EN 60903 2) Embossed Company Logo. "UGVCL" 3) Marking for " Use for 11KV" 4) UGVCL Logo on packing bag.
13	Warranty	One year

- The bidder has to submit following along with bid.
 - 1) Authorized Dealership letter from OEM.
 - 2) Confirmation letter for Guarantee/Warranty certificate from OEM at the time of delivery of the material.
 - 3) Test Certificate of various tests as per Clause No. 8: General Testing of EN - 60903 from approved lab.
- Following test/s is to be carried out at ERDA on tender sample as per the clause No. 5.3 (Electrical Requirements) of EN 60903.

Sr No	For use in	Class	Thickness	Proof Test (KV-rms)	Leakage Current at Proof Voltage	Working Voltage (rms)	Withstand voltage (KVrms)	L.Current at Working Voltage
1	11 KV	I	1.5 mm	10KV	16mA	7500V	20 KV	8000 micro Amp.

However, UGVCL reserves right to carry out any other test/s as per relevant IS/Specification on tender sample.

Signature of Tenderer:		
Date:	Place:	