

AMENDMENT NO.-2

- **Read clause No. 3.3 of Schedule-A as “vendor registration certificate is not applicable to this tender for purchase of LTDB SMC box.”**

- **Read clause No.3.1 of technical specification as under.**
“The minimum size of box from inside shall be for 200 Amp. 570X280X215 mm and thickness minimum 2mm & for 400 Amp 650X350X255 mm and thickness minimum 2mm”. Dimension shown in the drawing shall be also be revised accordingly.

Date:

Seal & Signature of Tenderer