



UTTAR GUJARAT VIJ COMPANY LIMITED



CORPORATE OFFICE, VISNAGAR ROAD, MEHSANA
PHONE NO : (02762) 222080 / 81 FAX NO. : (02762) 223574
Web Site : www.ugvcl.com / www.gseb.com E-mail : corporate@ugvcl.com

Manufacturer's Name
and Address.

G.T.P
TECHNICAL INFORMATION AND GUARANTEED TECHNICAL
INFORMATION FOR SUPPLY OF LT SHACKLE INSULATORS.
PART-'A'

Bidder has to confirm following important requirement.

| Sr.No. | Particulars | Confirmation |
|--------|---|--------------|
| 1 | Insulator shall be manufactured as per IS: 1445/1977 (Second revision) with amendment No.1 & 2. | Yes |
| 2 | Size of Insulator 90 x 75 mm. type-I Fig-3 of IS: 1445/77. | Yes |
| 3 | Dry power frequency withstand voltage 23 KV RMS. | Yes |
| 4 | Wet power frequency withstand voltage 10 KV RMS. | Yes |
| 5 | Power frequency puncture withstand voltage KV RMS i.e. 1.3 x the actual dry freshover voltage. | Yes |
| 6 | Mechanical failing load 11.5 KN (Min). | Yes |
| 7 | Tolerance in dimension as per relevant IS-1445/1977 (Second revision) with amendment No. 1 & 2. | Yes |
| 8 | Marking on insulator as per Clause No.6. | Yes |
| 9 | Packing of insulators as per Clause No.7. | Yes |

'PART-'B'

Bidder has to furnish below details about material.

1. Colour of glazed of L.T.Shackle Insulator.
2. Type of firing the insulator.
3. Details of test conducted on raw material.
4. Quality assurance plan which are being implemented.

Signature & seal of tenderer.

PART-'C': ENCLOSURES :

Bidder has to enclose following documents and has to confirm for the same.

| Sr.No. | Particulars | Confirmation |
|--------|---|--------------|
| 1. | 2 Nos. (Two) of sample for L.T.Shackle Insulator to be sent with tender. | Yes |
| 2 | Type test certificate covering all the tests as per Cl.No. 5.2 of Tender specification from Govt. approved laboratory. | Yes |
| 3 | List of Plant & Machinery | Yes |
| 4 | List of Testing equipments | Yes |
| 5 | List of orders pending/executed atleast for past two years for the items offered a) With GEB b) With the purchases other than GEB | Yes Yes |

PART-'D'

Bidder has to mention below deviation if any, quoting relevant clause of specification.

Signature & seal of Tenderer.

SPECIFICATION FOR L.T.SHACKLE INSULATORS

1. SCOPE :-

This specification covers the details of the L.T.Shackle White glazed/brown glazed insulators for use on 230/440V overhead lines and to supply within the Regional Store within the territory of Gujarat State.

2. APPLICABLE STANDARDS :-

IS-1445/1977 (Second revision) (Amendment No. 5) and its latest amendment if any but without the porosity test.

3. GENERAL REQUIREMENT :-

3.1 The porcelain shall be sound and free from defects, thoroughly verified and smoothly glazed.

3.2 The glaze, unless otherwise specified shall be brown/white in colour, Except the parts on which the porcelain is supported during firing, which may please be left unglazed, all other surface of the insulators shall be effectively glazed.

3.3. The design of the insulators shall be such that stresses due to expansion and contraction in any part of the insulator shall not lead to deterioration.

3.4 The insulator shall be in one piece.

4. INSULATOR CHARACTERISTICS :-

The insulators shall have the electrical and mechanical characteristics given in Trade-I of IS-1445/1977 and as under :-

| Sr. No. | Type of Insulator | Dry P.F Withstand voltage KV RMS | Wet P.F Withstand voltage KV RMS | P.F Puncture withstand voltage KV RMS | Min load KN | Failing |
|---------|-------------------|----------------------------------|----------------------------------|--|-------------|----------|
| 1 | Shackle | 23 | 10 | 1.3 x the actual dry flash over voltage. | 11.5 | (Type-I) |

N.B. :- Size of shackle 90 x 75 mm as per Fig. 3 Type-I of IS : 1445/1997.

Signature & seal of Tenderer.

5. TESTS :-

The Insulator shall comply with the following tests as per IS : 1445/1977 (Second revision Amendment No. 1 & 2).

5.1. Routine Test :-

The following shall be carried out as routine test.

Visual Examination :-

This test shall apply to all insulators.

5.2 Type Tests : (ISCL No. 8.1)

The firm shall submit the type test report from Govt. approved laboratory not more than five years old along with offer .The following type tests are to be carried out on two nos of samples in the order mentioned bellow as per IS 1445/77

a)Test on the both insulator,

- i). Visual examination. (8.4)
- ii). Verification of dimensions. (8.5)
- iii). Dry power frequency withstand test. (8.6)
- iv). Wet power frequency voltage withstand test. (8.7)
- v). Temperature Cycle test. (8.8)

b) Test on first insulator,

- i). Mechanical failing load test (8.9)

c) Test on second insulator,

- i). Power frequency puncture withstand test (8.10)

NOTE :- The identification marks of firm provided on the insulator should be invariably mentioned in the type test certificate.

5.3 Acceptance Tests :-

The test samples after having withstood the routine test shall be subjected to the following acceptance tests in the order indicated below :-

- a) Visual examination. (8.4)
- b) Verification of dimensions. (8.5)
- c) Temperature Cycle test. (8.8)
- d) Mechanical failing load test (8.9)

6. Marking :-

Each Insulator shall be lightly and indelibly marked to show the following.

- a) Name and Trade Mark of the manufacturer.
- b) Year of manufacturing.
- c) Word 'UGVCL'.
- d) Minimum failing load in KN.

Marking on porcelain shall be printed and shall be applied before firing.

7. Packing :-

Each Insulator should be wrapped with dry grass. This shall be then packed in either polythene or double gunny bags. No.of insulator should not be more than 50 in one bag.

Signature & seal of Tenderer.