



Save Energy for Benefit of Self and Nation

**UGVCL**  
**Uttar Gujarat Vij Company Ltd.**

Near Railway crossing, Old Power House, Division Office Vijapur-382870



(To be filed by the Contractor) Rs. \_\_\_\_\_

(2) Earnest Money Deposit  
Paid vide DD No. \_\_\_\_\_ Date \_\_\_\_\_ Rs \_\_\_\_\_

(3) GST No. \_\_\_\_\_ Date:- \_\_\_\_\_

**SCHEDULE: B (PRICE BID)**

**Name of Work: - Erection of Earth Terminal at Consumer premises by labour charge at Mansa Sub Division under the area of UGVCL, DO-Vijapur.**

Sr. No.	ITEM CODE	Description of works	Unit	Quantity	Labour Rates for works	Total Amount
1	2	3	4	5	6	7
1	9902040002	Labor charges for providing earth terminal at the consumer premises. Scope of work:- (1) Each earth terminal shall be provided by digging a pit of 1800mm x 600mm x 600mm. The pit shall be at least 1200mm far from the nearest support. The contractor shall lower the earthing coil/ C I plate provided by the company to the pit and make connection through to the external terminal of the metering point. The pit will be filled in by alternate layers of wood charcoal and salt cubes each of 30cms till the 1500MM from bottom or will be filled by betonies powder. Remaining 300mm shall be refilled by earth dug out. The contractor shall have to provide Wood charcoal (10 KG approx.) and the salt cubes (10 KG approx.) or betonies powder (25 KG approx.) his own. Earthing should be done as per REC standard, specification and as per attached drawing (2) The remaining material like Earth lead GI wire to the earth terminal of the metering point, Rigid PVC pipe to cover the lead wire, C I earthing plate / coil, sundries material like G I Nut bolts etc., shall be provided by the company. Earthing value must be less than 5 ohms. Above Earthing is to be connected with earth terminal of Meter Box by GI Wire No-8 & Exposed Parts of GI Wire Should be passed through a Rigid PVC Pipe.	NO.	1193	419.00	499867.00
		<b>Total Rs. (A)</b>				<b>499867.00</b>
		<b>Bidder's Offer (+ / -) in % (B)</b>				
		<b>Grand Total C = A +/- (A x B)</b>				

Save Energy for Benefit of Self and Nation

**UGVCL**  
**Uttar Gujarat Vij Company Ltd.**

Near Railway crossing, Old Power House, Division Office Vijapur-382870



Sr. No.	ITEM CODE	Description of works	Unit	Quantity	Labour Rates for works	Total Amount
1	2	3	4	5	6	7
		(GST Rate: _____%) $D = C \times \text{GST} \%$				
		SAC Code:				
		Grand Total including GST [ $E = C + D$ ]				
		Final Offer (in Rs.):				
		Final Offer (in Words):				

1. The Bidder Shall quote FIRM PRICES only. The Prices quoted will not be subject to any escalation till completion of work.
2. The Above prices are inclusive of all taxes, levies Duties etc. except Goods & Services Tax (GST). GST will be paid extra as applicable from time to time on a given taxable goods and/or services.
3. Work to be carried out as per site situation & instruction of Engineer In charge and within the jurisdiction of Vijapur Division.

Contractor's signature with seal. EXECUTIVE ENGINEER

Vijapur Division, UGVCL.

*Save Energy for Benefit of Self and Nation*

**UGVCL**  
**Uttar Gujarat Vij Company Ltd.**

Near Railway crossing, Old Power House, Division Office Vijapur-382870



### **General Condition:**

- (1) GI wire No:- 8 CI plate/earthing coil & earthing bolt/M.S. Bolt with nut & washer provided by UGVCL.
- (2) In case of no availability of earthing bolt, contractor shall have to be provided 2.5X5/8 Inch M.S. nut bolt for connection of GI wire No-8 & CI plate/earthing coil. The market value will be paid to contractor for providing M.S. nut bolt separately.
- (3) Wood charcoal, salt cubes shall be provided by Contractor.
- (4) Sundries material like as PVC pipe, bend, saddle clamp, round lugs shall be provided by contractor as required to cover GI No-8 from ground to metering point. Saddle clamp shall be provided at an interval of maximum 1.5 fit distance.
- (5) One HD rigid PVC pipe provided by UGVCL to cover GI 8 No from Ground level of Earthing pit.i.e.one earthing one pipe. After that remain open GI 8 no Wire shall be covered by Good Quality of PVC PIPE (electric fitting pipe) and bend having diameter 20 mm & 1.5m.m thick provided by contactor.
- (6) Work shall be carried out as per instruction of in charge engineer.
- (7) Connection wise A/C of material of CI plate/earthing coil & GI wire No-8 bolt/M.S. Bolt with nut & washer shall be maintained.
- (8) The work should be executed in presence of representative of UGVCL.
- (9) The company/Representative will not be responsible if accident occurred during the work.
- (10) Contractor should observe labor laws as per prevailing rules of Govt. of Gujarat.
- (11) If necessary order of one S/Dn. Will be transferred to other S/Dn. Depending upon requirement of UGVCL VIJAPUR Division.
- (12) Transportation of labor/Material for the work should be done by contractor.
- (13) For any dispute jurisdiction of legal will be at Vijapur DO.
- (14) UTTAR GUJARAT VIJ COMPANY LTD, reserves the right to reject any or all Tenders

Save Energy for Benefit of Self and Nation

**UGVCL**  
**Uttar Gujarat Vij Company Ltd.**

Near Railway crossing, Old Power House, Division Office Vijapur-382870



without assigning any reason thereof.

(15) Income Tax at prevailing Rate will be deducted as per Income tax Act.

(16) The rates are inclusive of PF and all other State/Central Government taxes. All type of Excise duty tax, sales/VAT tax, Service replaced by GST.

Name of Terms & Conditions	To be added/ amended
Tender Fee	Plus applicable GST
Prices	Replace Excise Duty, VAT/Sales Tax by GST
Excise Duty	Replace Excise Duty, VAT/Sales Tax by GST
Sales/VAT (Value Added Tax)	
Octroi	To be deleted

Signature of Tenderer  
With Rubber Stamp.

EXECUTIVE ENGINEER  
Vijapur Division, UGVCL.

### **GENERAL INSTRUCTION TO TENDERERS**

#### **Pre-Qualification:-**

Tender fee +GST as applicable

**A)** The contractor should be registered under the Goods & Service Tax. The contractor not Having GSTIN shall not be considered for acceptance of the Tender.

**B). PRICES:** - The Bidder shall quote FIRM PRICES only. The prices quoted will not be subject to any escalation till completion work. The above prices are inclusive of all taxes, levies, Duties etc. except Goods & Service Tax (GST) will be paid extra as applicable from time to Time on a given taxable goods and/or services. Also please mention **SAC Code** and rate of GST as Applicable.

#### **C).GOODS& SERVICE TAX(GST):- UGVCL GST No. is:-24AAACU6551F1Z1**

The firm prices are exclusive of Goods & service Tax as applicable. The amount and rate (%) of GST as applicable should clearly be indicated separately. (GST means all applicable Tax/cess under GST laws. GST Laws means IGST Act, GST (Compensation to the State for Loss of Revenue) Act CGST Act, UTGST Act and SGST Act-2017 and all related ancillary legislations). Contractor should charge GST in invoice at the rate as agreed to/mentioned in acceptance of tender only any deviation in the same shall not be accepted. Further, any additional liability of GST (later on due to wrong mentioning of GST rate, mis-interpretation of HSN/SAC Code etc.Over and above as charged in the invoice shall be borne by the contractors. However any refund received by the contractor on account of GST charged from the company; such refund shall have to be passed on to the company, along with interest if any. Such refund along with interest needs to be passed on suo-moto by the contractor. Further, the company has a right to recover the amount of GST along with penal interest at the rate of 15% per annum or interest/fees & penalty charges under GST Law, whichever is higher if GST charges is not paid/short paid to the Government or failed to upload the details or uploads inaccurate particulars on GSTIN portal by the contractor within

Save Energy for Benefit of Self and Nation

**UGVCL**  
**Uttar Gujarat Vij Company Ltd.**

Near Railway crossing, Old Power House, Division Office Vijapur-382870



the stipulated time limit.

**D). STATUTORY VARIATION:-**Any statutory increase or decrease in GST as applicable or in the event of introduction of new tax/cess or cessation of existing tax/cess subsequent to the offer if it takes place within the original contractual completion date will be to Company's account subject to the claim being supported by documentary evidence. However, if any decrease takes place after the contractual delivery date, the advantage will have to be passed on to COMPANY.

**E). PENALTYS FOR DELAYS:-**The delivery, erection and commissioning periods (as applicable) shall be guaranteed under penalty clause mentioned below. Any delay that may take place in erection and commissioning activities beyond contractual out of date shall be subject to penalty at the rate of 2% of the contract value (of delayed materials/works) per month or part thereof subject to a maximum of 10% of total contract value, Plus GST as applicable.

**Bidders shall have to furnish relevant documents for payment of GST as applicable along with each RA. Bill.**

**\*SPECIAL INSTRUCTION: -** With tender you are required to submit copy of EMD Receipt, License copy, Original Solvency Certificate, PAN Card copy/GST registration Certificate copy. If you are lowest than, you have to pay 5/10 % Security deposit of order value. Execute the agreement, Indemnity Bond, Sub order may be issue after complete the above official tender formalities.

#### **CONDITIONS:**

Bidder has to submit tender in one Envelop and in this two different covers should be put. One cover mentioning **Technical bid** on it & another cover mentioning **Commercial Bid** on it. If we receive envelop that do not have two separate sealed covers than those bids are liable to be rejected. Technical bid should be submitted with documents as under, failing which tender is liable for rejection.

#### **Following Documents must attached with Tender copy:-**

- (i) Solvency certificate issued from any Nationalized Bank amounting to sum equivalent of estimated cost. (Minimum 5 Lakh).
- (ii) Separate EPF code No. allotted by RPFC & Last Six month of current year EPF Challan paid copy is required.
- (iii) Latest income tax clearance certificate. With PAN card. (Assessment Year 2018-19)
- (iv) Labor license certificate.
- (v) Experience:-Contractor should produce evidence of executing similar nature & magnitude of work i.e. **Domestic consumer earthing** from any DISCOM of GUVNL. The Experience certificate of minimum 1 **(One)** Year and satisfactory completion of work; issued by Executive Engineer of respective division is require.
- (vi) Group Insurance A copy of the insurance policy of the insured laborer's under W.C.

*Save Energy for Benefit of Self and Nation*

**UGVCL**  
**Uttar Gujarat Vij Company Ltd.**

Near Railway crossing, Old Power House, Division Office Vijapur-382870



Act.

- (vii) Details of equipment's available with the tendered & Tools & tackle Certificate
- (viii) Valid Electrical contractor license.
- (ix) Turn over details year wise on CA Letterhead At least 2 years. And at least Rs. 5 Lacks turn over required in bank statement for current year.
- (x) GST registration no must be submitted with tender.
- (xi) Nationalized bank's Demand Draft of Tender Fee and EMD.
- (xii) UGVCL VENDOR REGISTRATION IS REQUIRED.

**Other Condition:-**

1. Add in Tender Copy that the Contractor have to implement all the provisions of contract Labor Act, PF and Minimum wages act, payment of wages act, Gratuity act, Bonus act & other Labor Laws.
2. Before placing the order Contractor have PF registration & Labor license.
3. Before starting the work contractor have to be submit copy of Group Insurance policy for labor.
4. After starting of work contractor have to be provided Register as per labor act & as per Provident fund act.
5. If contractor failed to implement above mentioned acts not provided required document Registers Than 20% of bill amount should be withheld from each bill.

**Signature of Tenderer**  
**With Rubber Stamp.**

**EXECUTIVE ENGINEER**  
**VijapurDivision,UGVCL.**


Save Energy for Benefit of Self and Nation

**UGVCL**  
**Uttar Gujarat Vij Company Ltd.**

Near Railway crossing, Old Power House, Division Office Vijapur-382870



**REC**  
**CONSTRUCTION STANDARDS**  
**J-1**



NOTE:-  
FOR PIPE EARTHING REFER CONSTRUCTION STANDARDS J-2.

ALL DIMENSIONS IN MM.

**COIL EARTHING**

SCALE:- H. T. S.

SEPT.- 1972



*Save Energy for Benefit of Self and Nation*

**UGVCL**

**Uttar Gujarat Vij Company Ltd.**

Near Railway crossing, Old Power House, Division Office Vijapur-382870

