

UGVCL UTTAR GUJARAT VIJ COMPANY LIMITED



CIN - U40102GJ2003SGC042906,GST No.-24AAACU6551F1ZI

SCHEDULE:B FOR LAYING OF UNDERGROUND CABLE NETWORK KADI-2 SDN PR-414502.					
Sr.No.	Description	Unit	Quantity	Rate per Unit in Rs.	Total Amount in Rs.
1	Laying (including installation, testing and commissioning) of various size of Single circuit 11 KV XLPE insulated Alluminum armoured Cable in ground 1200 mm deep and 300 mm wide trench, providing sand cushioning below (75 mm thick layer of sand) and above (75 mm thick layer of sand) of the cable and covering it with RCC half round Hume pipe (150 mm inner diameter with thickness of 30 mm and One meter in length) before refilling pre-bonding tap/warning tap should provide below 700 mm from the ground level and back filling the same to make ground level as per original. As per specification and drawing of UGVCL. (RCC half round pipe should be provide throughout on cable without gap). Only Cable will be supplied by UGVCL.	MTR	500	335	167500
2	Laying (including installation, testing and commissioning) of various size of Double circuit 11 KV XLPE insulated Aluminum armoured Cable in ground in single trench 1200 mm deep and 500 mm wide trench, providing sand cushioning below (75 mm thick layer of sand) and above (75 mm thick layer of sand) and above (75 mm thick layer of sand) of the cable and covering it with RCC half round Hume pipe (150 mm inner diameter with thickness of 30 mm and One meter in length) before refilling pre-bonding tap/warning tap should provide below 700 mm from the ground level and back filling the same to make ground level as per original. As per specification and drawing of UGVCL. (RCC half round pipe should be provide throughout on cable without gap). Only Cable will be Supplied by UGVCL.	MTR	50	468	23400
3	Labour work for laying of HT cable open from air grounding to gentry including carting.	MTR	100	38	3800
4	Supply and Installation of clamps made from 50*6 mm GI flat (Minimum weight of flat 1.6 Kg per Set) for fitting for 110 mm GI/HDPE Pipe above ground with the Pole including cost of nuts & bolts.	SET	50	130	6500

Schedule - B



UGVCL UTTAR GUJARAT VIJ COMPANY LIMITED



CIN - U40102GJ2003SGC042906,GST No.-24AAACU6551F1ZI

5	Supply and Installation of clamps made from 50*6 mm GI flat (Minimum weight of flat 1.8 Kg per Set) for fitting for 160 mm GI/HDPE Pipe above ground with the Pole including cost of nuts & bolts.	SET	50	150	7500
6	Laying of various sizes of 11 KV XLPE insulated Aluminium armoured Cable in Cable Tray/ Trench over/below the ground level excluding Cable Tray/Trench.	MTR	300	150	45000
7	Laying of HDPE Pipe confirming to IS 4984:1955 (Amendment no. 2) having 160 mm Diameter and minimum 5 mm Thickness at a minimum Depth of 1200 mm below the road surface by Push through method, drilling the road with HDD machine/manually without breaking the road surface and laying of any size of HT XLPE insulated Aluminum armoured Cable through the duct as per the instruction of EIC and specifications excluding cost of HDPE Pipe. Only Cable will be supplied by UGVCL. (For 240 & 300 mm2 XLPE cable)	MTR	400	800	320000
8	Supply of HDPE Pipe having 160 mm Diameter and minimum 5 mm Thickness confirming to IS 4984:1955 (Amendment no. 2) for laying of 11 KV XLPE Cable.	MTR	400	640	256000
9	Laying of HDPE Pipe confirming to IS 4984:1955 (Amendment no. 2) having 160 mm Diameter and minimum 5 mm Thickness at a minimum Depth of 1200 mm below the road surface by Push through method, drilling the road with HDD machine/manually without breaking the road surface and laying of any size of HT XLPE insulated Aluminum armoured Cable through the duct as per the instruction of EIC and specifications including cost of HDPE Pipe. Only Cable will be supplied by UGVCL.	MTR	100	1440	144000
10	Laying of HDPE Pipe confirming to IS 4984:1955 (Amendment no. 2) having 110 mm Diameter and minimum 5 mm Thickness at a minimum Depth of 1200 mm below the road surface by Push through method, drilling the road with HDD machine/manually without breaking the road surface and laying of any size of HT XLPE insulated Aluminum armoured Cable through the duct as per the instruction of EIC and specifications including cost of HDPE Pipe. Only Cable will be supplied by UGVCL.	MTR	100	1350	135000



UGVCL UTTAR GUJARAT VIJ COMPANY LIMITED



CIN - U40102GJ2003SGC042906,GST No.-24AAACU6551F1ZI

11	Supply of HDPE Pipe having 110 mm Diameter and minimum 5 mm Thickness confirming to IS 4984:1955 (Amendment no. 2) for laying of 11 KV XLPE Cable.	MTR	500	525	262500
12	Laying of HDPE Pipe confirming to IS 4984:1955 (Amendment no. 2) having 110 mm Diameter and minimum 5 mm Thickness at a minimum Depth of 1200 mm below the road surface by Push through method, drilling the road with HDD machine/manually without breaking the road surface and laying of any size of HT XLPE insulated Aluminum armoured Cable through the duct as per the instruction of EIC and specifications excluding cost of HDPE Pipe. Only Cable will be supplied by UGVCL. (For 70 & 185 mm2 XLPE cable)	MTR	500	825	412500
13	Laying of Medium grade B Classs GI Pipe having 110 mm Diameter at a minimum Depth of 1200 mm below the road surface by Push through method, drilling the road with HDD machine/manually without breaking the road surface and laying of any size of HT XLPE insulated Aluminum armoured Cable through the duct as per the instruction of EIC and specifications including cost of GI Pipe. Only Cable will be supplied by UGVCL.	MTR	100	1240	124000
14	Supply and Fixing of Medium grade GI Pipe having 110 mm Diameter and minimum length 2.5 meter required having weight 9 to 10 kG/Mtr.	MTR	0	925	0
15	Laying of Medium grade B Class GI Pipe having 160 mm Diameter at a minimum Depth of 1200 mm below the road surface by Push through method, drilling the road with HDD machine/manually without breaking the road surface and laying of any size of HT XLPE insulated Aluminum armoured Cable through the duct as per the instruction of EIC and specifications including cost of GI Pipe. Only Cable will be supplied by UGVCL.	MTR	52	1490	77480
16	Supply and Fixing of Medium grade GI Pipe having 160 mm Diameter and minimum length 2.5 meter required having weight 10 to 11 kG / Mtr.	MTR	50	800	40000
17	Providing and Fixing of Heat Shrikable Indoor Termination Kits for for 3-Core, 11 KV XLPE Aluminium armoured Cable as specified with connection of leads including cutting, stripping of cable, insulations, providing compression type	NO			



UGMCL



UTTAR GUJARAT VIJ COMPANY LIMITED CIN – U40102GJ2003SGC042906,GST No.-24AAACU6551F1ZI

	terminal, crimping of lugs with suitable crimping				
	tool. (Quality make of Raychem / 3M (M-Seal) /				
Δ.	Densons / Vikchem etc.) 70 mm2 HT XLPE Cable	NO	1	4710	4718
<u>A</u>		NO	5	4718	
В	185 mm2 HT XLPE Cable	NO	5	4953	24765
C D	240 mm2 HT XLPE Cable 300 mm2 HT XLPE Cable	NO	1	5252	26260 5549
U		NO	1	5549	5549
	Providing and Fixing of Heat Shrikable Outdoor Termination Kits for 3-Core, 11 KV XLPE Aluminium				
	armoured Cable as specified with connection of				
	leads including cutting, stripping of cable,				
18	insulations, providing compression type terminal,				
	crimping of lugs with suitable crimping tool.				
	(Quality make of Raychem / 3M (M-Seal) / Densons				
	/ Vikchem etc.)				
A	70 mm2 HT XLPE Cable	NO	1	5664	5664
	185 mm2 HT XLPE Cable	NO	25	5982	149550
	240 mm2 HT XLPE Cable	NO	25	6378	159450
	300 mm2 HT XLPE Cable	NO	1	6676	6676
	Providing and Fixing of Heat ShrikableStright	_			
	Jointing Kits for for 3-Core, 11 KV XLPE Aluminium				
	armoured Cable as specified with connection of				
4.0	leads including cutting, stripping of cable,				
19	insulations, providing compression type terminal,				
	crimping of lugs with suitable crimping tool. (
	Quality make of Raychem / 3M (M-Seal) / Densons				
	/ Vikchem etc.)				
Α	70 mm2 HT XLPE Cable	NO	1	7199	7199
В	185 mm2 HT XLPE Cable	NO	5	7655	38275
С	240 mm2 HT XLPE Cable	NO	5	7880	39400
D	300 mm2 HT XLPE Cable	NO	1	8040	8040
	Providing and Fixing of "Route marker" of CC 1:2:4,				
	150 mm X 150 mm X 750 mm Concrete stone				
	embedded in earth at least 300 mm below the GL	MTR	MTR 50		20000
	and 450 mm above GL at distance of approximately				
20	100 Meter or as directed by engineer in charge.			400	
20	The route marker must be painted with yellow			400	
	colour of stone with red colour for embracing on				
	stone –"UGVCL 11 KV Cable" including material,				
	painting &labour charges for excavation& refilling.				
	TOTA	L AMOUI	NT OF TEN	IDER = Rs.	2520726.0
	100				