

**OPEN TENDER**

**NIVIDHA NO. MSNCO/108/2022**

TO,

PR NO :- 501255

RFQ NO :- 68935

M/s \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

**Name of Works:- Erection & Maintance work of HT,LT & TC For Mehsana City SDn,under Mehsana D.O,UGVCL.**

Executive Engineer Mehsana,UGVCL, has invited Tender for Labour charges for erection work of HT, LT line and T/C under Mehsana City Sub-Division for various scheme of Mehsana Division as per Schedule-B as and when require. (Work to be carried out in other sub-division in case of emergency as per instruction of Engineer-In-Charge) Details of the Tender are as under.

1	Tender Notice No.	
2	Tender Item	Item Rate
3	Estimated cost	1000000.00
4	Time Limit	24 Months
5	Tender fee ( Non refundable) by Cash or D.D.	<b>500+18% GST= 590/-</b>
6	Earnest Money Deposit (By Cash or D.D.)	11800.00 (1.18 % of Estimated cost)
7	Security Deposit (For successful bidder)	59000.00 (5.90 % of Estimated cost )
8	Online Preliminary, Technical & Price bid i.e. On line (e-tendering) tender/offer submission last date	Date: 17/08/2022 Up to 18.00 Hrs
9	Relevant documents (By Registered Post A.D. or Speed Post only) submission date	On or before date 20/08/2022 Up to 18.00 Hrs
10	Date of opening of Tender fee, EMD cover and Technical Bid physical as well as online(if possible)	Date 22/08/2022 up to 12.00 Hrs
11	Date of On line Opening of Price Bid (Tentative, if possible)	Date 22/08/2022 up to 16.00 Hrs

**Note:**

1. Tender & relevant documents are to be sent by R.P.A.D / Speed Post - Otherwise tender will not be accepted.
2. Date of D.D. for Tender Fee and EMD must be on or before last date and time of on line submission of tender.
3. Price bid if submitted in physical form, same will not be opened and only online submitted price bid will be considered for evaluation.
4. All the bidders, in respect of the tender item must have vendor registration with the UGVCL / GUVNL or their subsidiary companies prior to the date of opening of technical bid. Otherwise

**Regd. & Corporate Office:**

Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**

Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

their bids will not be considered eligible for technical scrutiny and as such, their technical bids will not be open.

5. Any technical questions, information and clarification that may be required pertaining to this tender should be referred to competent authority.
6. UGVCL reserves the right to reject any OR all tenders without assigning any reasons thereof.

Supdt. A/C.  
D.O Mehsana .UGVCL

Executive Engineer  
D.O Mehsana .UGVCL

**The contractor will have to give the following undertaking on Rs.100/- notarized stamp paper:**

1. If this tender be accepted, contractor shall agree to abide by and fulfill all the terms and provision of the Tender and contract of works as applicable and in default thereof to forfeit and pay to the Company the sum of money due.
2. The value of EMD paid herewith should be absolutely forfeited to the company, if contractor fail to deposit the full amount of specified security deposit, within specified time limit.
3. The contractor shall co-operate with the Company in recording measurement etc. as expeditiously as possible. He shall fulfill all the requirements which are necessary to finalize his outstanding bills within one month from the date of completion of work, failing which the Company shall finalize the account on the basis of its records and pay him such amount. The amount of security deposit if any remaining payable to him after deducting there from the amount due by him to the Company's for shortages of materials, rectification, incomplete work, etc and the Company shall not entertain any further claim from him thereafter.
4. The competent authority can delete any item in schedule "B" in the tender, if he feels that the rate quoted by the contractor for that item is abnormally high when compared to the estimated rate.
5. In case of any dispute, EE/SE will be the final authority for deciding the same and his decision will be final and binding on the contractor and Department and no further appeal will be entertained.
6. The contractor will have to see that safety equipments are used by his labours, while working on the line, equipment etc. of the Company and contractor will be responsible for any accidents.
7. The contractor will have to under taken responsibility of accidents etc. for his persons working on the line and same will be on notarized stamped paper of Rs.100/- or the appropriate value (if revised by Gove) in case of contract awarded. The cost of stamped will be borne by contractor.
8. The contractors will have to take insurance of suitable amount for his labours.

**Regd. & Corporate Office:**  
Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**  
Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

9. Contractors will have to carry out the work under his eligible and authorized supervisor. However the work is to be done as per standards and under supervision of UGVCL.
10. The Company does not bind itself to accept the lowest or any tender neither with any reason be assigned for the rejection it is also not binding on the company to disclose any analysis reports on the tender.

I/We hereby agreed and bound for all above conditions mentioned.

Name of Contractor:

Signature

Full Address:

Contact Detail

Place:

Date:

### **Important instructions for submitting the Tender**

- 1.0 Executive Engineer Mehsana,UGVCL has invited Tender for Labour charges for erection work of HT, LT line and T/C under Mehsana City Sub-Division for various scheme of Mehsana Division from the contractors / firms who have executed works of similar nature and magnitude successfully and who are registered under appropriate class.
- 2.0 **Physical submission of Tender documents shall be in two parts system i.e. (1) EMD and Tender fee cover and (2) Technical Bid cover.**
- 2.1 **Technical bid** is to be submitted in a separate sealed envelope and subscribing the envelope as **"Technical Bid"**. Technical bid should be submitted with all required documents as under, failing to which bid is liable for rejection; following documents dully attached should be submitted for pre qualification criteria.

#### **Pre-Qualification criteria for selection in Technical Bid (To be submitted with Technical bid.)**

- (i) Solvency certificate issued from any Nationalized Bank amounting to 25 % equivalent of estimated cost (as per UGVCL Rules).
- (ii) Separate EPF Code No. allotted by RPFC & Last Six month of current year EPF Challan paid copy is required.
- (iii) Vender Registration certificate in appropriate class as contractor in UGVCL. Bid of the bidder without vender registration, will not be consider for further evaluations.
- (iv) Last three financial year income tax return copy.

**Regd. & Corporate Office:**  
Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**  
Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

- (i) NO Experience Require. But Contractor has Experience related this work , so attached work order copy last finically year or Work complete certificate not Below Executive Engineer Rank.

➤ **Technical Criteria for awarding the contract to qualified bidder are as under**

- a) The mandatory criteria of experience and work executed for respective category shall have to be fulfilled as under.

Sr. No.	Type of category	Minimum DISCOM Erection work executed total experience in amount in last 5 year	Minimum Experience in Years	Valid Contractor License	Bid Capacity
1	Class-AA	Minimum Rs. 40.0 lakhs	Three	Required	Any amount
2	Class-A	Minimum Rs. 25.0 lakhs	Two	Required	Up to 30 Lakhs
3	Class-B	Mini. Rs. 10.0 lakhs	One	Required	Up to 20 Lakhs
4	New	New	Fresh	Required	Up to Rs. 10 Lakhs

- (ii) Group Insurance:-A copy of the insurance policy of the insured labourer's under W.C. Act 1923.  
 (iii) The contractor will have to under taken responsibility of accidents etc. for his persons during working on the line and same will be on notarized stamped paper of Rs. 100/- or the appropriate value (if revised by Govt.) The cost of stamped will be borne by contractor.  
 (iv) List of Tools & Tackles and safety equipments available with contractors as per Annexure-B.  
 (v) Copy of the Electrical contractor license.  
 (vi) Labour license  
 (vii) GST Registration No.  
 (viii) PAN No.  
 (ix) Contractor's Store address along with proof  
 (x) Other documents (if required by authority)

**Those bidders who have successfully submitted all above requirements are to be considering for further evaluation.**

- 3.0 Earnest money deposit of Rs. 11800.00 should be submitted in form of Demand Draft in favour of UTTAR GUJARAT VIJ COMPANY LIMITED drawn on any scheduled Bank, payable at Mehsana.

Tender without earnest money deposit is not liable to be considered.

Earnest money deposit will be forfeited in case the successful bidder after his tender has been accepted shall refuse to pay the prescribed security deposit and execute the contract.

- 4.0 The bidder shall have to submit the complete tender documents in all respects duly signed and sealed.  
 5.0 The bidder shall have to submit their offer without any deviations in general terms and conditions of the contract or in Technical specification/items. Tenders of such deviations may also be rejected. Incomplete and conditional tenders shall not be considered.  
 6.0 UTTAR GUJARAT VIJ COMPANY LIMITED reserves the right to split up the work covered in the scope of this contract amongst more than one contractor

- 7.0 Intending bidders should submit their tenders after studying all tenders documents carefully and visiting the site for satisfying themselves of actual site conditions, location and accessibility of site and nature, extent of the work involved etc. Submission of tenders implies that bidders have obtained all necessary information and other data required for executing the work. . No claim for extra charges on account of any misunderstanding or otherwise will be allowed.
- 8.0 All approaches to the site shall be in the scope of bidders.
- 9.0 The successful bidder will not be allowed to give sub-contract of the works awarded to him for any reasons what so ever without permission of the Engineer-in charge.
- 10.0 Price quoted shall be firm, till overall completion of the work under contract and there will not be any price escalation.
- 11.0 Date of opening of "Price Bid" will be intimated later on to those Bidders who are qualified in technical bid. "Price bid" of only qualifying bidders on the basis of Technical bid shall only be opened. Price of bidders, who are not qualified technically as per requirement of technical bid shall not be opened.
- 12.0 Offers shall be valid for the **period of 120 days from** the date of opening of price bid. Bidders shall not withdraw tenders during the validity period, failing which their EMD shall be forfeited during the **period of 120 days.**
- 13.0 All the works shall be carried out as per specifications attached with the tender as per REC standards & Drawings. All materials procured (if required) should be confirming to relevant Indian Standard issued by Bureau of Indian Standard.
- 14.0 Tenders, who do not fulfil all or any of the conditions of the tender found incomplete in any respect, are liable to rejection.
- 15.0 Uttar Gujarat Vij Company Ltd. Reserves the right to reject any or all tenders without assigning any reason thereof.

Signature of Contractor  
Name of Seal, Details Add.  
With Cell No/Fax

Executive Engineer  
UGVCL, D.O.Mehsana

**TECHNICAL SPECIFICATIONS FOR THE WORK TO BE CARRIED OUT**

**For erection work 11 KV and L.T. Distribution lines and Transformer Centers.**

**(a) Erection of HT and LT Lines:**

Site clearing and tree cutting, which come in the way of line, will be done by the contractor at his cost. The Company will assist the contractor in getting necessary permission for tree cutting etc. Any claim for compensation in above respect will have to be borne by contractor.

**(b) Fixing of Pole Location:**

The position of pole structures, guys and earthing will be fixed by the department and will be shown to the contractor. He should adhere to these locations in all circumstances unless directed by the department to make any change.

**(c) Pole setting:**

Where poles are set in good solid ground, the depth of pit shall be 1/6 the height of the pole and for grounds of any other nature, depth of pit shall be decided by the department. The poles and guys must not be set at the edge of cuts or embankment where the soil is liable to be washed or eroded out such setting should be avoided. While back filling, proper care should be taken for filling of pit.

Extra payment is payable for hard soil or rock under the pole erection item which may be quoted in the tender. The cost of damage done to the pole during erection will be recoverable from the contractor. Pole, which is out of plumb, shall not be accepted.

He should be able to render full account of the poles entrusted to him whenever the Supervising Officer demands to scrutinize the same.

**(d) Erection of Complete single Pole Structure**

Erection of single pole structure comprises of shifting of pole from the stacking place in the village, excavation of pit, erection in position (with base plate where required), of 8 meter, 10 meter PSC poles, 9 meter to 13 meter long rail or suitable size girder or any other suitable pole, fitting of clamps and cross arms and fabricated materials, fixing of caution boards as per drawing, numbering and anti climbing device. Generally vertical formations will be used on each pole. However horizontal formations will have to be used in special circumstances as per instruction of Engineer in charge.

**(e) Special Two Poles Structure**

Special two poles structure such as for HT line tapping, Railway crossing, any other HT/LT or telephone line crossing, terminal structure for transformer substation comprises of Excavation suitable pits and refilling of earth erection in position of two nos. of 8 Meter to 10 Meter PSC poles. 9 meter to 13 Meter long rails or any other suitable poles fitting of clamps and cross arms, bracing, cross bracing etc. as per drawing exclusive of mounting transformer but inclusive of mounting D.O. fuses/ A.B. switches, numbering fixing of caution Board and anti climbing device etc. The D.P. must be properly aligned and must be in plumb. Special structure if included will be erected as per drawing supplied.

**(f) Stringing of conductors**

This includes stringing of stranded and solid bare conductor with fitting of necessary HT/LT Pin and strain insulators, binding on insulators, jumpering. The jointing in HT line will be done properly as per standard practice. Care must be taken in handling the conductor to protect against cuts, scratches or kinks. The conductor must not be drawn over rough or rocky ground, when it is liable to be damaged.

Wastage and cutting should be avoided as far as possible. Not more than 2% sag will be accepted in the materials account drawn for proper tension. The sag and spans will be maintained as per drawing and design. The cross arms insulators must be so fixed that neither tilts nor bands from position. The rate quoted should be per conductor route kilometer.

The span and sag, however, may vary according to sizes of pole available that these dimensions will be specified by the field Engineer before commencement of work. The sagging should be uniform for all conductors and uneven sagging will not be allowed.

All the clearances should be maintained as per IE Rules 1956.

**(g) Erection of Stay Set:**

The erection of stay set comprises of excavation of suitable pit of 4' depth burying stay rods with CC block, anchor plate, fixing of stay clamp on pole, fixing of turn buckle, binding of GI stay wire, fixing of stay insulators on all stay as per drawing. No stay should be left loose, but should be tightened and made straight to withstand in cyclone or sand storm, the item includes refilling of earth.

**(h) Earthing:**

The earthing arrangement shall be of pipe type/ plate type/ coil type as indicated in the drawing. The earthings are to be done at place as indicted in the pole schedule or selected by the field Engineer. Coal and salt will have to be supplied by the contractor at his cost. Erection of earthing should be carried out by digging separate pit of 6 feet for each earthing under the supervision of the in charge. No amount will be paid if the work is not done in accordance with these instructions. At least 10 KG of charcoal and 10 KG of salt should be invariably used by the contractor at his cost and refilled the earthing pit with the alternate layers of coal / coke and earth. Earthing carried out in pit of pole will not be considered and no amount will be paid for such type of earthings.

**(i) Guarding:**

The guarding will have to be provided between crossing of HT and LT lines, at the road crossing, crossing of telephone and telegraphs line and such other places as indicated by the department. The work comprises of fixing of guard cross arms, eye bolts, guard cradle as per design, GI cross lacing wires complete. Any special type of guarding if required will be designed and erected by the contractor as per requirement of department.

**(j) Painting:**

Rail poles and girder poles shall be applied by one coat of approved red-lead paint after cleaning

the surface and two coats of approved aluminum paint. All steel mounting will also be painted in same manner. There should be sufficient interval between every coat of painting in order to allow for drying. In order to differentiate the first and second coat of Aluminum paint, azure blue tube must be added to the first coat of aluminum paint at the rate of ½ tubes per gallon of paint to give bluish tinge. The bolts must be dipped in anticorrosive oil before insertion. The lower portion of steel poles up 3' above ground level shall be cleaned of all dust and rust. This surface should be given a base coat of red lead and an additional coat of black bituminous paint before inserting in the ground. The paints will be supplied by the contractor and should be of I.S.I marking or of Jonson, Nicholson or Asian Paints or such other well known make and will be got approved from Executive Engineer, prior to starting work. Feeder name on poles should be painted in block figures of 3" size with a good paint in Gujarati at a height of about 8' from the ground level.

**(k) Concreting / Muffing:**

The proportion for muffing of poles and stay rods should be 1:2:4 (cement one part, sand two parts and four parts machine crush metal black trap). One finishing coat of cement plaster should be applied on outer surface of the muffing. The location and shape of concerting will be decided by the Engineer-in-charge and the contractor will follow his instructions scrupulously. If the concerting work is not found as per the specifications and quality, the same is liable to be rejected. The muffing has to be done in the presence of companies representative only and work done in his absence will be rejected and no payment made thereof. Cement, sand, metal & water shall be procured by the contractor.

**The size of muffing for various size of pole shall be as per Annexure C-1 for new erection work/ Annexure C-2 for maintenance work**

**(l) TRANSFORMER SUBSTATION:**

The transformer substation will be of outdoor type mounted on two poles structures as per standard drawing and comprises of,

- Erection of poles with necessary earthings.
- One set of HT D.O fuses/ AB Switch.
- 11KV 10 to 200 KVA transformers complete with its accessories.
- One set of HT lightning arrestors.
- Fixing of Distribution box, cross arms and branching with earthing as per drawing, necessary wiring of appropriate size of cables.
- Stays with insulators, numbering, fixing of danger board and ant climbing device.
- Three independent separate pipe type earthing/plate earthing / coil earthing should be provided on either side of the transformer center and one at middle of the transformer center. One separate earthing for LA, one separate earthing for transformer neutral and one separate earthing for transformer body and other metal parts including distribution box. Each consisting of one or more earth connection to earth pit.
- The rate should be quoted inclusive of transportation of distributions transformer from the Company's stores to the site of erection. The cost of damage done to the transformer is recoverable from contractor.

**(m) Stringing of HT/LT Arial Bunched Cable**



This includes stringing of Aerial Bunched Cable with providing and fitting of necessary accessories like dead end clamps, suspension clamps, insulation piercing connectors, Eye Hooks, HT termination kits, jumpering etc. Care must be taken in handling the cable to protect against cuts, scratches or kinks. The cable must not be drawn over rough or rocky ground, when it is liable to be damaged.

**(n) INSTRUCTIONS TO BE FOLLOW BEFORE STARTING WORK**

Before starting the work (New, alteration or addition) and during the progress of works the contractor must obtain line clear whenever necessary from the concerned officers of this department or other. During transportation or erection, if any accident occurs or any liability arises due to non observance of rules / instructions, contractor will be responsible for that.

All conductor, earth wire and stay set must be tight. Stay rod pit must be as per the specifications. The entire pole must be in plumb. Fabrication fitting on pole must be tight. Generally following span should be kept.

- 50 to 60 Meter for HT line
- 40 to 50 Meter for LT line

All road crossings must be provided with **bridge ling** arrangement and minimum 22-Ft. Clearance must be kept between conductor and road level.

So long as the line is not handed over to the company, the responsibility of its safe custody and of all fixture and materials etc. lying with that of the contractor will be that of the contractor.

**PROCEDURE TO BE FOLLOW FOR GETTING MATERIAL FROM STORES**

**A. Issue of materials:**

The following materials shall be supplied by the UGVCL free of cost for use on the works to the contractor as required from RSO / Divisional Stores as well as from the sub-division store if any. The transportation will have to be arranged by the contractor at his cost (except poles of all types.)

**List of Materials:**

1. Conductors.
2. The pole will be supplied by UGVCL at convenient place near place of work within 5 KM.
3. HT/LT insulators with hardware.
4. Fabrication item of required sizes.
5. Stay wire, G.I wire, earthing plate, earthing coil, earthing bolt, earthing pipes.
6. Distribution Transformer, LT Dist. Box, lightning arrestors, HT D.O. Fuse, AB switch with accessories, PVC cable.

7. Danger board, anti climbing device of barbed wire.

8. Stay set material.

The rates quoted should be inclusive of required all type of bolts and nuts (except LT Shackle bolt) and transportation cost of all type of materials to site from the stores. The following material will be supplied by the contractor at his cost for which no payment will be made.

- B. The quantities in the Schedule are approximate. Actual quantities may increase or decrease according to the local conditions. The department reserves the right for revising or omitting any of the quantities to be erected during the execution.
- C. The contractor will draw and will be given only those materials and in anticipated quantities that are just sufficient for the works to be carried out by him. The contractor should first intimate his requirement to the concerned field Engineer who will approve the list and as per this list, the materials can be drawn from the stores.
- D. The materials will be issued to the contractor himself or his duly authorized representative only. The contractor at the time of taking materials from the stores shall have to give letter of authorization in triplicate to the concerned sub-divisional officers, specifically stating the names of the persons who will draw materials from the store on his behalf and would sign the requisitions for and on behalf of the contractor and shall be binding upon the contractor. In case if any authority or power of attorney is to be terminated, written instructions in this respect must be intimated by Registered Post to the Executive Engineer and concerned sub-divisional office.
- E. The contractor must get the requisition, three days before requires the materials on site, from the Engineer-in-charge, for the material as per technical sanction. All the materials mentioned in the requisition should be issued from Divisional store to the name of contractor with scheme. No any material should be drawn departmentally for the work allotted to the contractor.
- F. In case of shortage or loss or damage to materials, the cost of the same will be recovered from the Contractor at stock issue rate or prevailing market rate at the time of finalization of bill whichever is higher plus 15% overhead charges with applicable TAXES.
- G. The contractor will be fully responsible for any damage, breakage, loss or theft of materials during transit or erection issued to him from stores till the time the work is handed over to and taken over by the Company. The cost of damage shall be recovered from him as stated above in F.
- H. All materials supplied to the contractor shall remain the absolute property of the company and shall on no account be removed from the site of the work and shall at all times be opened to inspection by the Engineer in-charge.
- I. Any such materials remaining unused and in perfectly good condition at the time of completion of the contract shall be returned to the company store for which no carting charges are payable to the contractor.

- J. The contractor will have to make his own arrangements to keep the materials under lock and key (i.e. Store) and address of all the stores to be submitted before commencement of work. He will be responsible for theft or loss on account of any reason what so ever.

All the above instructions have been read by me thoroughly or have obtained the thorough understanding of the same and are acceptable to me unconditionally.

### **GENERAL TERMS & CONDITIONS**

- 1) The work should be strictly as per specifications and approved drawings of the Company which can be supplied by the Engineer In-charge for reference at the request of the contractor. The inferior and unsatisfactory work is liable to be rejected.

Before commencing the erection of lines, the contractor will be provided with the schedule and the detailed layout map (proposed sketch). The work will have to be carried out as per programmed laid down by department and under the entire supervision of UGVCL's deputed supervisor and contractor should employ his supervisor who could supervise the works throughout and he should remain present on site.

Marshy or water logged locations must be avoided as far as possible. If it becomes inevitable to locate poles at such points, special precautions about foundation will have to taken and work carried out as per instructions of the Engineer In-charge.

The spans shall be specified in the pole schedule and the minimum spacing between the phase conductors and conductors & neutral shall be as per norms.

No tools will be supplied by the department. The work if found inferior and not up to standard of the Company's is liable to be rejected at the risk and cost of the contractor. Any expenditure incurred for rectification work carried out departmental/Labour will be recovered from contractor's bills, if the contractor fails to rectify the inferior work done by him in spite of the instructions to rectify the same.

Contractor will have to submit the certificate of their supervisor under whose supervision the work has been carried out.

**2) Acceptance of Tenders:**

The Company does not bind itself to accept the lowest or any tender, neither will any reason be assigned for the rejection. It is also not binding on the Company to disclose any analysis reports of the tenders.

Accepting authority reserves the right of rejection of any or all tenders without assigning any reason thereof.

Any tender who does not comply with the above requirements is liable to be rejected.

**3) Security Deposit:**

The successful bidder shall have to pay security deposit of 5.90 % of estimated cost within 15 days from the date of LOA.

**4) Contract Document:**

The successful bidder, whose tender is accepted will have to execute a stamped agreement in standard form with the company and will have to sign the contract booklet viz. Tender and contract for works at his own cost. In case of partnership firms, necessary partnership documents, in original along with its copy will have to be produced for verification along with authority to sign the bills measurement and enter in to contract as well as correspondence with the company. Wherever required necessary power of attorney will have to be produced especially when the partnership deed is silent on the point of authority to deal with the Company. The contractor will have to execute the documents and sign the booklet "Tender and contract for work" before starting the work.

**5) Jurisdiction:**

Any dispute of differences arising under out of or in connection with the contract shall be subject to the exclusive jurisdiction of Mehsana.

**6) Additions and alterations of any kind in tender forms, conditions etc by the bidder without the consent of the undersigned are not permissible.**

**7)**

- a. The bidder must quote his rate per unit specified in the schedule in figures as well as in words. If there is difference between rates quoted in words and figures, rates quoted in words shall prevail.
- b. The bidder must quote his rates net lowest and the rates not confirming to the unit specified in schedule may not be considered even though they may be lowest.
- c. The rates must be stated for each item separately and in addition percentage of reduction in the total price if any should also be quoted.

**Regd. & Corporate Office:**

Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**

Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

d. Any variation in rates etc will not be allowed on any ground once the tender submitted is opened for consideration.

8) The rate quoted should be in percentage higher /lower / rate to rate.

9) The company's general conditions of contract will apply to all the contractors and he is deemed to be fully aware of the company's general conditions of contract for the works in respect of security deposits, penalty for late completion of work etc and any ignorance of these conditions will not exempt the contractor from the liability to abide by the same.

Submission of a tender by the bidder implies that he has read that the instructions and conditions of contract contained in booklet and has made himself aware of the scope and specification of the work to be done and of the conditions and rate at which stores etc. will be issued to him and local conditions and other factors bearing on the execution of work.

If the contractor stands lowest for more than one tender it will be at the discretion of the competent authority whether to award more than one work or not without assigning any reason thereof.

10) In case of any discrepancy between Tender Document condition and the General Conditions of Contract attached to Tender Document, the condition mentioned in tender document is final.

11) Any amount payable by UGVCL / Any Circle Office of UGVCL / Any Division office of UGVCL under any order / sub work order to the contractor can be adjusted against amount receivable by UGVCL / Any Circle Office of UGVCL / Any Division office of UGVCL / GUVNL or any of its subsidiary company. The contractor will have no objection whatsoever for the same.

12) **Safety:-**

Before starting any work by the labour of the contractor, it will be the responsibility of the contractor to obtain line clear from the concerned officer.

The Company is not liable for any injury on damage to contractor's workman or his equipment respectively during execution of this contract and the Company will not pay any compensation for any reasons whatsoever. The contractor is also responsible for any damage to private property i.e. standing crops in farms or Gram Panchayat property etc.

No any work should be carrying out without supervisor of the company for safety point of view. Contractors should observe all the safety rules during execution of work.

The contractor will have to see that labours working on the site should utilize all safety equipment like helmet, safety belt, hand gloves, safety shoes and tool-tackle. If any labour found without safety equipment at site during execution of work, it is fully responsibility of contractor for any accident occurred.

13) The contractor shall not demand or accept any help from the intending consumers in line erection works or in transportation of materials.

14) Whenever there is an excess work carried out by a contractor beyond the technically sanctioned amount against the work order given, the approval for the excess quantity of work done should be obtained from the competent authority as per Company rules.

15) The erection work should be started from the date of commencement given in the order and should be completed within the prescribed period for each work. The contractor is bound to complete the work within the specified period of each separate work order given by Executive Engineer.

The contractor will be given the separate order for each work on the basis of the rate contract order. The date of commencement and date of completion of work will be mentioned in the order, which the contractor has to agree; otherwise the penalty will be levy for the late completion of work as per Company standard conditions. Time limit of separate work order will be considered from last date of material issued.

16) **Extension of Time Limit:**

In case of delay in work is beyond the control of the contractor and he is not in a position to complete the work within the stipulated period, he should give in writing to Engineer in charge within seven days from the occurrence of the event for giving extension in time limit.

17) In case of any non supply of materials from stores, the contractor will have to intimate the SDO as the Division office quoting the MR No and date for non receipt of materials. The intimation will be considered for extension in time limit. The time limit will be considered on the basis of number of "Working Days" or "Months".

It will be the responsibility of the contractor to intimate the closing down and recommencement of work at all stages to the engineer in charge or vice versa in writing with due reason for the closing down of the work with specific of days for which work will remain closed.

In case of failure on the part of the contractor, his claim for extension of time limit will not be entertained.

In case of no intimation in this regards the reason for delay on this ground will not be accepted.

18) Priority of work would be decided by the Executive Engineer and contractor shall carry the work within the stipulated period of the order given by the Executive Engineer.

19) The contractor must have adequate resources and manpower of skill/unskilled personnel to undertake the work at different places simultaneously.

20) The contractor will submit the final bill/ sub-work order bill within two months from the work completion date.

21) The payment will be release within thirty days after submission of bill or all relevant documents with invoice or part thereof whichever is later.

- 22) If during 12 calendar months from the date of handing over charge after completion of work, the erected lines are found defective in any way, the same should be rectified by the contractor.
- 23) The contract will remain in force for the period of one year from the date of issue of work order. However, before completion of work against existing order, new tender is invited for same jurisdiction as mentioned in existing order and if rate received lower, than price matching is required.
- 24) **TERMS OF PAYMENT:**
- a) The payment will be made to the contractor by crossed Cheque on local bank or by ECS/RTGS/NEFT subject to an advance stamped receipt being received from payee.
- b) The payment will be done after successful completion of scope of work of each sub-work order after furnishing of the material accounts.
- 25) **Recording of measurements**
- a) If the work has been carried out satisfactorily, the contractor with prior intimation from the Company Officers shall have to witness the recording of measurements on the appointed date within the month of the completion of work. If contractor fails to come to the appointed date a notice under Registered cover with A.D. will be served on him to witness the recording of measurement prior appointment with the Company officer within ten days of receipt of notice or within such extended period applied for by the contractor and granted by the Company Officer. If the contractor still fails to come for the recording of measurements within the original or extended period of time granted by the Company officer then the recording of measurements will be carried out thereafter unilaterally by the Company Officer and the same shall be finalized as per measurements, recorded by the Company's Officer and the same shall be binding on the contractor, no request then will be entertained.
- b) In case, work not carried out satisfactorily either during the progress of work or on its completion, the conditions as specified vide condition mentioned in tender and contract for works booklet shall apply and the recording of measurements shall be done within one month of completion of work after rectification of defect by contractor or by the Company at the contractor's costs as the case may be and any further delay in the recording of measurements and finalization of the final bill as mentioned in the contract book let.
- 26) **Submission of materials account by contractor:**
- The contractor shall submit material account with each bill. Also he shall on completion of the work have to prepare and render the final detailed material account of the materials received by him from the Company store within one months from the date of completion work, if however the contractor does not render the material accounts a notice shall be issued to the contractor under Registered A.D. to render the materials account within ten days from the date of issue of the notice. On default, the material account will be finalized and the recovery made as per the Company account and procedure which shall have to be accepted by contractor and disputes if any raised shall not be entertained. The balance materials also will have to be returned by the contractor within one month from the date of completion of work otherwise Company is not liable to accept at a later date.

The contractor will not be allowed to transfer materials from one work to another without the written permission of the field officer justifying the reasons for such transfer.

The contractor will have to use the materials on the work for which they have drawn.

- 27) Any rules framed or instructions issued regarding contractors by the Company or its representative after awarding this contract shall also a part of this contract and will be binding to the contractor.

On completion of work the contractor will inform the concerned DE in writing and DE will see that if any rectifications are to be required, will intimate to the contractor within 15 days in writing from the date of receipt of the letter from the contractor to complete the rectification works within 7 days. If the contractor fails to do the rectification additions or alterations etc within the above time limit, than the same will be got done through other agency or departmental staff at the risk and cost of the contractor without giving any further notice or any intimation. No complaint will be entertained from the contractor in this regard and amount will be recoverable with 15% supervision charges.

- 28) Contractor has to take Earthing certificate from the UGVCL supervisor (Line Staff) and it is to be submitted along with the final bill.

29) **Rate to be deducted for not carrying out the work (As per SOR Rate)**

- a) If Feeder name is not done as per standard specifications due to negligence from contractor side in that case rate of **Rs.50/-** per location will be deducted from the bill.
- b) Charges for mounting distribution boxes are including in erection of T/C. If distribution box with wiring is not issued by UGVCL in that case **Rs. 300/- per number** shall be deducted from the bill.
- c) If Transformer is not mounting then **Rs. 1500/- per** transformer or actual expenditure for mounting transformer, whichever is higher will be deducted from the bill.
- d) **If earthing of pole or DP structure is not found in a separate pit as per standard then such bill will not be recorded.**
- e) If PSC pole exists than **Rs.250/-** per pole shall be deducted.
- f) If Girder pole exists than **Rs.480/-** per pole shall be deducted.
- g) If DP structure exists than **Rs.500/-** per pole shall be deducted.
- h) **Lighting arrestor must be installed otherwise bill will not be recorded.**
- i) All empty conductor drums will have to be returned by the contractor at concern Divisional Stores, failing which **Rs.100/-** per drum will be recovered.
- j) GST at the applicable rate will be added to rates / amounts mentioned above.



30) Tax deducted at the source (TDS) under Income Tax and under Goods and Service Tax Act will be deducted from bill as per applicable rate, if applicable.

31) **STATUTORY VARIATION:**

Any statutory increase or decrease in the taxes and duties including GST and Cess as applicable or in the event of introduction of new tax/cess or cessation of existing tax/cess subsequent to contractor offer if it takes place within the original contractual delivery date will be to COMPANY's account subject to the claim being supported by documentary evidence. However, if any decrease takes place after the contractual delivery date, the advantage will have to be passed on to COMPANY.

Statutory Variation clause shall not be applicable in case of Supplier / Contractor has opted for Composition Scheme under GST.

32) **ARBITRATION:**

All questions, disputes or differences whatsoever which may at any time arise between the parties to this agreement touching the agreement or subject matter thereof, arising out of or in relation there to and whether as to construction or otherwise shall be referred to the decision of the Sole Arbitrator, as appointed by the MD of COMPANY, for that purpose, who shall be a retired High Court Judge or retired District and Sessions Judge, and the decision of the said Arbitrator shall be final and binding upon the parties. Reference to the arbitration shall be governed by the provisions of Indian Arbitration & Conciliation Act. 1996 as amended from time to time and the rules made there under.

33) **CARTEL:**

If, the Company during the procurement process, observes or suspects any activity on the part of bidders or obtains any knowledge which indicates the existence of cartel formation amongst the bidders or apprehends the possibilities of cartel as defined under The Competition Act, 2002, the Board of the Company being a government Company involved in public procurement work, reserve all rights to allot quantities to such bidders, who are not part of the cartel, in any manner deemed fit in the interest of the Company without assigning any reason thereof.

Besides the above the purchaser Company, may initiate actions under the Competition Act/other laws and / or the bidder(s)/ firm(s) will be black listed / stop deal, at its sole discretion.

34) **Evaluation of Tenders:-**

Tenders shall be called for in two bids: (1) Techno-commercial Bid and (2) Price Bid.

The price Bid of Techno-commercially qualified Bidders will be opened.

For modification or relaxation in Techno-commercial Conditions after Technical Bid is opened, all Bidders shall be given equal opportunity.

35) **Price Evaluation:-**

All Tenders shall be evaluated on firm Price End Cost with Tax (GST or any other tax) basis unless otherwise mentioned in the Tender documents.

**Regd. & Corporate Office:**

Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**

Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

- 36) If work is not started / completed within stipulated time limit period, then contract be short closed with applying risk purchase and Security Deposit is to be forfeited with put on black listing or stop deal for the period decided by the competent authority.

**PR-501255**

**SCHEDULE : B**

**RFQ- 68935**

**Name of work : Erection & Maintance work of HT LT & TC For Mehsana City SDn,under Mehsana D.O,UGVCL**

**Memorandum showing items of Erection work with rates quantity & amount.**

Sr. No	Description of Work	Estimate Qty.	Unit	TENDER RATE in Figure	Total
1	2	3	4	5	7
1	<b>HT Tapping</b> from the Existing Pole including Fixing of Cross Arms, Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing <b>Code.9901000001.</b>	30	No	313	<b>9390.00</b>
2	Erection of <b>PSC POLES of 8 Mtr X 200 KG</b> including Fixing of PIT and refilling of Earth, fixing of cross Arms, Top Fitting Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing . <b>Code.9902010001</b>	100	No	757	<b>75700.00</b>
3	Erection of <b>PSC POLES of 10 Mtr X 270 KG</b> including Fixing of PIT and refilling of Earth, fixing of cross Arms, Top Fitting Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing . <b>Code.9902010002</b>	30	No	1815	<b>54450.00</b>
4	Erection of <b>Steel Poles of 9 Mtr to 11 Meters</b> including Fixing of PIT and refilling of Earth, fixing of cross Arms, Top Fitting Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing. <b>Code.9902010003</b>	10	No	1268	<b>12680.00</b>

**Regd. & Corporate Office:**  
Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**  
Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

5	Erection of <b>Steel Poles of 13 Meters</b> including Fixing of PIT and refilling of Earth, fixing of cross Arms, Top Fitting Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing <b>Code. 9902010005</b>	5	No	1453	<b>7265.00</b>
6	Erection of Double POLES structure of 8 Mtr X 200 KG PSC Pole including Excavation of PIT and refilling of Earthing, fixing of Channels, Supporting Angles, Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing Code. 9902020003	2	No	1720	<b>3440.00</b>
7	Erection of Double POLES structure of 10 Mtr X 200 KG PSC Pole including Excavation of PIT and refilling of Earthing, fixing of Channels, Supporting Angles, Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. Complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing Code. 9902020025	2	No	4030	<b>8060.00</b>
8	Erection of Double POLES structure of 9 Mtr To 11 Meter Steel Pole including Excavation of PIT and refilling of Earth, fixing of Channels, Supporting Angles, Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. Complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing Code. 9902020010	2	No	2485	<b>4970.00</b>
9	Erection of Double POLES structure with mounting of AB Switch, HG Fuses of 8 Mtr X 200 KG PSC Pole including Excavation of PIT and refilling of Earth, fixing of Channels, Supporting Angles, Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing Code. 9902020003	2	No	2067	<b>4134.00</b>
10	Erection of Double POLES structure with mounting of AB Switch, HG Fuses of 9 Mtr TO 11 Meter Steel Poles including Excavation of PIT and refilling of Earth, fixing of Channels, Supporting Angles, Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing. Code. 9902020010	2	No	2712	<b>5424.00</b>
11	Erection of Double POLES structure with mounting of AB Switch, HG Fuses of 13 Meter Steel Poles including Excavation of PIT and refilling of Earth, fixing of Channels, Supporting Angles, Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing Code. 9902010005	2	No	3080	<b>6160.00</b>

**Regd. & Corporate Office:**  
Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**  
Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

12	Erection of SINGLE POLE structure with mounting of AB Switch, HG Fuses, Transformers, Lightning Arrestors, Distribution BOX ETC. of 8 Mtr X 200 KG PSC Pole including Excavation of PIT and refilling of Earth, carting of Transformers from Store to Site, Fixing of Channels, Supporting Angles, Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing. Code. 9902030003	2	No	2949	5898.00
13	Erection of DOUBLE POLE structures with mounting of AB Switch, HG Fuses, Transformers, Lightning Arrestors, Distribution BOX ETC. of 8 Mtr X 200 KG PSC Pole including Excavation of PIT and refilling of Earth, carting of Transformers from Store to Site, Fixing of Channels, Supporting Angles, Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing.	30	No	5900	177000.00
14	Erection of DOUBLE POLE structures with mounting of AB Switch, HG Fuses, Transformers, Lightning Arrestors, Distribution BOX ETC. of 10 Mtr X 200 KG PSC Pole including Excavation of PIT and refilling of Earth, carting of Transformers from Store to Site, Fixing of Channels, Supporting Angles, Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing. Code. 9902030003	2	No	7430	14860.00
15	Erection of DOUBLE POLE structures with mounting of AB Switch, HG Fuses, Transformers, Lightning Arrestors, Distribution BOX ETC. of 9 Mtr to 11 Meter STEEL Poles including Excavation of PIT and refilling of Earth, carting of Transformers from Store to Site, Fixing of Channels, Supporting Angles, Clamps Anti-Climbing Devices, Danger board, Insulators, ETC. complete and Painting of Fabricated materials and numbering of pole, complete As per standard specification but excluding erection of GUY set and Earthing. Code. 9902030007	2	No	6899	13798.00
16	Erection of GUY SET including Excavation of PIT and refilling of Earth, AS PER STANDARD SPECIFICATION WITH STAY CLAMPS, STAY WIRE, ANCHOR ROAD, TURN BUCKLE, EYE BOLT, GUY INSULATORE, CC BLOCK ETC. Code.9902040001	2	No	364	728.00
17	CONCRETING OF POLES, GUYS, ETC. INCLUDING COST OF CEMENT SAND METAL (1:2:4) AND WATER ETC. AS PER STANDARD SPECIFICATION	1	CMT	5900	5900.00
18	Erection of COIL TYPE/ CI PLATE TYPE EARTHING INCLUDING COST OF COAL SALT ETC. BUT WITHOUT COST OF GI WIRE AS PER STANDARD SPECIFICATION Code. 9902040002	200	No	419	83800.00
19	STRINGING OF 30MM2 ACSR/34MM2, 55MM2 AAA CONDUCTOR FOR 11/22KV & LT LINES INLCUDING FIXING OF INSULATORS, BINDING JUMPERING ETC. Code. 9903000001	5	Km	1373	6865.00

**Regd. & Corporate Office:**  
Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**  
Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

20	STRINGING OF DOG. CONDUCTOR FOR 11/22KV & INCLUDING FIXING OF INSULATORS, BINDING JUMPERING ETC Code. 9903000001	5	Km	3162	15810.00
21	PROVIDING OF 1-ph NEW CONNETIN WITH PVC 2.5 MM2 CABLE FROM TERMINAL POLE TO METERING POINT INCLUDING FIXING OF METER, MMB(SMC) SERVICE PIPE, GI WIRE NO-10,EGG INSULATOR REEL INSULATOR WITH METEREARTHING COMPLETE WORK AS PER STANDARD SPECIFICATION ETC. Code. 9912020008	20	No	258	5160.00
22	Providing Three phase 4 wire service connection with PVC 4mm2/10mm2 four core cable from terminal pole to metering point including fixing of meter with meter earthing complete work as per slandered specification but excluding cost of material Code. 9912020008	20	No	355	7100.00
23	PROVIDING GUARDING TO HT LINE/LT LINEON ROAD / RAIL CORSSING.CODE-9906000001	30	Meter	58	1740.00
24	LT LINE TAPPING SINGLE PHASE (WHERE ADDITIONAL NUT BOLTS & FABRICATIONS/U- CLAMPS FITTING IS REQUIRED Code. 9901000002	50	No	32	1600.00
25	LT LINE TAPPING THREE PHASES (WHERE ADDITIONAL NUT BOLTS & FABRICATIONS/U- CLAMPS FITTING IS REQUIRED Code. 9901000002	50	No	59	2950.00
26	Stringing / Laying of overhead LT cable for road crossing HT line crossing & telephone line crossing ETC. Code. 9906000001	100	No	162	16200.00
27	Dismantling of 8 Mtr. PSC POLE in usable Condition with crediting of fabrication at STORE & STACKING OF POLE AT SAFE AND ON ROAD SIDE.CODE-9907000017	50	No	511	25550.00
28	Dismantling of 10 mtr psc pole/ 13 MTR. GIRDER SIZE 100X150 MM IN USABLE CONDITION WITH CREDITING OF FABRICATION AT STORE & STACKING OF POLE AT SAFE AND ON ROAD SIDE Code. 9907000017	20	No	1028	20560.00
29	Dismantling of transformer centre (PSC Pole) with crediting of fabrication materials & Transformer at store and safe stacking of pole at road side with Transformer Code. 9907000007	5	No	3025	15125.00
30	Dismantling of transformer centre (PSC Pole) with crediting of fabrication materials & Transformer at store and safe stacking of pole at road side. Without Transformer Code. 9907000007	5	No	2057	10285.00
31	CARTING OF PSC POLE AT DESTINATION (PER POLE) MORE THAN 4 KM & UP TO WORK DESTINATION Code. 9914020002	50	LS	246	12300.00
32	Replacement of 11 KV PIN INSULATOR by new pin insulator /Composite Pin Insulator with Binding Code. 9908000002	2000	No	31	62000.00
33	Replacement of 11 KV DISC INSULATOR WITH H/W by new Disc Insulator / Composite Disc insulator As per Specification. Code. 9908000003	300	No	106	31800.00

**Regd. & Corporate Office:**  
Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**  
Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

34	Replacement of LT Shackle insulator By New One. Code. 9908000008	100	No	21	2100.00
35	Re Fixing OF V cross arm in proper positions. Code. 9911000010	100	No	41	4100.00
36	Replacement of V cross arm By New One. Code. 9911000010	100	No	139	13900.00
37	Re Fixing of Top fitting arm in proper positions Code. 9911000010	100	No	27	2700.00
38	Replacement of Top Fitting Bye New One Code. 9908000002	100	No	34	3400.00
39	Straighting of tilted PSC Poles/ RSJ Poles at Pin Point Code. 9911000002	10	No	189	1890.00
40	Straighting of tilted PSC Poles/ RSJ Poles at tension Point Code 9911000002	10	No	207	2070.00
41	Re-Tightening of loose GUY set in all aspects. Code. 9911000007	20	No	104	2080.00
42	Re-Jumpering work of HT/LT LINE for SHACKLE POLE, TAPPING DO AB SWITCHES AS PER SPECIFICATION Code. 9911000031	50	No	59	2950.00
43	Erection Of Support pole (PSC/RSJ) for stay (i.e. stud Pole). 9911000002	10	No	418	4180.00
44	PIN BINDING OF CONDUCTORE & CLEANING OF 11 KV PIN INSULATOR AS PER INSTRUCTION OF ENGINEER INCHARGE Code. 9911000004	100	No	12	1200.00
45	PIN BINDING OF CONDUCTORE & CLEANING OF LT SHACKLE INSULATOR AS PER INSTRUCTION OF ENGINEER INCHARGE Code. 9911000004	50	No	9	450.00
46	Converting Pin Point to Shackle point including dismantling & restringing etc including the cost of Nuts & Bolts Code. 9908000118	10	No	1619	16190.00
47	Removal / Dismantling of Existing HT/LT line conductor from line 34/55 MM2 and crediting to store. Conductor has to dismantle from shackle to shackle pole, with minimum nos. of cut piece as instruction of Engineer incharge. Code. 9907000009	5	Per Cond Per KM	650	3250.00
48	Removal / Dismantling of Existing HT/LT line conductor from line DOG 100 MM2 (Above 55MM2 size conductor) and crediting to store. Conductor has to dismantle from shackle to shackle pole, with minimum nos. of cut piece as instruction of Engineer in charge. Code. 9907000009	5	Per Cond Pe KM	1450	7250.00
49	Re-stringing of HT & LT line (34 mm2 to 55mm2) conductor/coated conductor with new pin binding (SPAN-35 MTR) Code. 9911000008	5	1 Wire per span	69	345.00
50	Re-stringing of HT & LT line (Above 55mm2 size conductor) conductor /coated conductor with new pin binding (SPAN-40 MTR) 9911000008	5	1 Wire per span	71	355.00
51	Trimming of TREE BRANCHES on strutting HT/LT line on one tree size more than 5 inch.	500	Per tree	35	17500.00

**Regd. & Corporate Office:**  
Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**  
Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

52	Trimming of bigger size of tree branches/whole tree on strutting HT/LT line Code. 9911000009	100	Per Day per Labour	315	31500.00
53	Stringing of 11 KV Aerial Bunch Cable size 70 to 120sqmm with fittings of all accessories, i.e. Special design suspension clamp fixing of cross arm, It scheckle insulator etc for fixing of Messenger wire complete, as required and directed by Engineer incharge. Code. 9913000017	2	Km	28994	57988.00
54	STRINGING OF ARIAL BUNCH CABLE (3c 16 to 95 sq mm) with fittings of all accessories, i.e. Special design suspension clamp fixing of cross arm, It scheckle insulator etc for fixing of Messenger wire complete, as required and directed by Engineer incharge. Code. 9913000016	1	Km	14707	14707.00
55	STRINGING OF ARIAL BUNCH CABLE (1c 16 to 95 sq mm) with fittings of all accessories, i.e. Special design suspension clamp fixing of cross arm, It scheckle insulator etc for fixing of Messenger wire complete, as required and directed by Engineer incharge. Code. 9913000016	1	Km	5883	5883.00
58	Numbering of pole with paint by preparing back ground of one colour & have lettering (Height 3" and width 0.5") as directed by engineer in charge. (Color to be used must have ISI mark, colour to be provided by contractor).code-9911000001.	2685	NO	28	75180.00
	Total Rs. (A)			Total	999870.00
				.....Bidders offer(+/-) in % (B)	
				Grand Total (C) = A +/- (A*B)	
				Goods and service Tax D= C x GST % GST Rate: ____% SAC Code:	
				Grand Total including GST E= C + D	
				Final Offer in RS.=	
				Final Offer RS. In words	

I/We hereby agree to carry out the work at:

- I) At estimated cost
- II) \_\_\_\_\_% Below Estimated Cost
- III) \_\_\_\_\_% Above Estimated Cost

Thus, my tender value is Rs. \_\_\_\_\_ (in words Rs. \_\_\_\_\_)

**Regd. & Corporate Office:**  
Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**  
Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

Above mentioned rate is inclusive / exclusive of \_\_\_\_% GST.

Signature of Contractor & seal

SA (Exp)  
Mehsana Division

Executive Engineer  
Mehsana Division

## Annexure-A

Name of Contractor:- \_\_\_\_\_ Mobile no: \_\_\_\_\_

Contractor's store address:-

(1) \_\_\_\_\_

(2) \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_

**Details of work completion (last five years):**

Sr. no	Name of work	Name of Division	Work order no. & Date	Tender Amt (Rs.)	Amount of work completed (Rs.)	Quantity of work completed		
						HT	LT	TC



**Details of work order on hand / Work under progress:**

Sr. no	Name of work	Name of Division	Work order no. & Date	Tender Amt (Rs.)	Amount of work completed (Rs.)	Quantity of work completed		
						HT	LT	TC

Contractor's Signature

-----For office use only-----

This is to certify that, the above contractor name as \_\_\_\_\_ has successfully completed work of above mention order in this division in stipulated time. The work is found satisfactory.

Executive Engineer

**Regd. & Corporate Office:**  
Visnagar Road, MEHSANA - 384001 Gujarat  
Telephone: (02762) 222080-81  
Fax: (02762) 223574  
e-mail: corporate@ugvcl.com

**Division Office:**  
Visnagar Road, Mehsana- 384001  
Telephone: (02762)222055  
e-mail: eemsndo@ugvcl.com

## Annexure-B

Name of Contractor:- \_\_\_\_\_ Mobile no: \_\_\_\_\_

**Details of Equipments, Tools, and safety equipments available with contractor:**

Sr. no	Name of Equipments, Tools, and safety equipments	Quantity in Nos.	Reg. no / Sr. no of equipment	Approximate value (Rs.)
1				
2				
3				
4				
5				
6				
7				
8				
9				

10				
11				
12				

Contractor's Signature