

PR No - 420754

RFQ - 59555

Amendment No. 1

Tender Ref No: UGVCL/PROJECT/REMAINING AREA OF BOL GIDC/UG/83

Bidders are hereby requested to note that following amendments & clarifications are made in **Various Clauses of Technical Specifications of Outdoor Packaged Sub Station** of “Turnkey Based Contract for Under Ground Power Distribution Network of Remaining Area of BOL GIDC of Sanand-II SDn of Bavla DO of Sabarmati Circle under UGVCL in Gujarat State”.

Sr. No.	Clause No.	Existing Provision of Clause	Proposed Amendment
1	1.2.1.1	The main equipment i.e. HT RMU, Transformer & LV Switchgear shall be as of the same make as of the compact substation.	The said clause is hereby deleted.
2	1.3	IEC 61330	IEC 62271-202
3	1.4.2 & 1.4.2.4	Temperature rise shall be 50/55 deg. C in oil/winding respectively over a maximum ambient of 50 deg. C	Temperature rise shall be 40/45 deg. C in oil/winding respectively over a maximum ambient of 50 deg. C as per IS 1180 (Part I): 2014.
4	1.4.3 c	Incoming / Outgoing: As per BOQ (Space should be available for 5 Nos. 400 A MCCB in outgoing)	Incoming: 1 no. of incoming having 800A, 4P, 65kA Fixed Type ACB with microprocessor based O/C, E/C & E/F release Outgoing: 6 nos. of outgoing having 250A, 3P, 36kA, MCCB. Suitable to connect 3.5C X 240 Sq. MM LT cable and neutral link to be provided to connect the neutral cable for each outgoing.
5	1.4.3 C	New Added	Meter is in scope of Supplier. Approved makes of Meter are, L&T / Genus / HPL / Registered Vendor & Regular Suppliers of GUVNL and its subsidiary companies.

This amendment duly signed and sealed to be submitted along with technical bid.

All other terms & Condition of tender remains same.

Documents are available on website <http://ugvcl.nprocure.com>

(For view, download & on line submission)

Addl. Chief Engineer (P&Re)
R&C Office, Mehsana