



**AMENDMENT No:-2**

**Tender Notice No: UGVCL/SP/I/1149/Boots**

**Amendment in Technical Specification and Extension in Due Date of Submission.**

(A) Bidders are requested to consider following Amendment in Technical Specification of Boot.

Sr. No.	As per tender specification	Amendment In Specification
1	As per Annexure-A GTP Silicon Grease – 1 bottle (30 ml aprx.)	<b>Silicon Grease</b> – 3 pouch (each having 5 gm)
2	Technical Specification 2.0 Design Feature <b>Length:</b> >300 mm (vertical Boot), <b>Cable/conductor Entry top of boot:</b> >Ø15 mm, <b>Thickness:</b> 4.5 ± 0.5 mm <b>Inside diameter of bottom of boot:</b> Ø72 mm <b>Inside diameter of Grommet:</b> Ø35 mm <b>Rain shade cable/conductor entry hole:</b> Ø10 mm	<b>Length:</b> Min. 300 mm (vertical Boot), <b>Hole for Cable/conductor Entry at top of boot:</b> Ø15 mm +/- 2 mm, <b>Thickness:</b> 4.5 ± 0.5 mm <b>Inside diameter of bottom of boot:</b> Ø72 mm +/- 2 mm <b>Inside diameter of Grommet:</b> Ø35 mm +/- 2 mm <b>Rain shade cable/conductor entry hole:</b> Ø10 mm +/- 1 mm
3	Technical Specification 2.0 Design Feature  The vertical cable boot should be fitted on the transformer bushing using a grommet. Grommets must have Slots for Water Passage and 3 legs attached to the grommet to ensure draining of water	The vertical cable boot should be fitted on the transformer bushing using a grommet. Grommets must have 3 Slots for Water Passage to ensure draining of water
4	GTP Point no. 15 ERP Tape- 3M make, 25 mm width, 2 meter long	<b>ERP Tape-</b> 25 mm width & 2 meter long (Make of ERP Tape : 3M, Scapa, Jacobs, Ascon)

➤ (B) **EXTENSION IN DUE DATE OF SUBMISSION**

<b><u>Sr. No</u></b>	<b><u>Description</u></b>	
1	Tender No.	UGVCL/SP/I/1149/Boots
2	Online Preliminary, Technical & Price bid i.e. On line(e-tendering) tender/offer submission last date (This is mandatory)	8.8.2022 up to 18.00 Hrs.. Extended Up to 23.08.2022 up to 18.00 Hrs.
3	Relevant documents (By Registered Post A.D. or Speed Post only) and sample Physically submission date.	12.8.2022 up to 18:00 Hrs.. Extended Up to 25.08.2022 up to 18:00 Hrs.
4	Date of opening of Tender Fee & EMD Cover Documents Physical as well as online	17.8.2022 at 11.00 Hrs.. Extended Up to 26.08.2022 up to 12:00 Hrs.
5	Date of opening of Technical Bid Physical as well as online	18.8.2022 at 11.30 Hrs. Extended Up to 29.08.2022 at 12.30 Hrs.
6	Date of On line Opening of Price Bid (Tentative, if possible)	25.8.2022 at 11.00 Hrs. Extended Up to 06.09.2022 at 12.00 Hrs.

This amendment is to be duly signed and sealed and to be submitted along with technical bid.

Other contents of tender notice, terms and condition, Specification of above tender remains unchanged.

Yours Faithfully

Chief Engineer (P&P)  
UGVCL: Mehsana

Date:

Signature & Seal of the Tenderer