


NOTE :-

- | | |
|------------------------------------|---|
| 1. APPLICABLE STANDARD DESIGNATION | IS 5300 / 1969
C FIG-3 |
| 2. COLOUR OF GLAZE | BROWN |
| 3. SIZE OF INSULATOR | MM 140 X 85 |
| 4. LENGHT | MM 140 |
| 5. DIAMETER | MM 85 |
| 6. CABLE HOLD | MM 25 |
| 7. MIN FAILING LOAD | KN 88 |
| 8. P.F. WITHSTAND VOLTAGE DRY KV | 27 (rms) |
| 9. P.F. WITHSTAND VOLTAGE WET KV | 13 (rms) |
| 10. MARKING AS PER IS | IS 5300 / 1969
38 KN
MONTH / YEAR |
| 11. ALL DIMENSION ARE IN | MM |

This is drawing given by Dval.

Chief Engineer (P & P)
U.G.V.C.L. R & C Office,
Mehsana.



DAKSHIN GUJARAT VIJ CO. LTD. SURAT.
DRAWING : HT- STAY (GUY) INSULATOR