

Save Energy for Benefit of Self and Nation

UGVCL

Uttar Gujarat Viji Company Ltd.

CIN – U40102GJ2003SGC042906

ANNEXURE – B

LIST OF TESTING INSTRUMENTS.

Sr. NO	ITEM	QTY	MAKE	SR. NO OF METER	RANGE	Accuracy	DATE OF Calibration	Lab.Report No & Date
1	RATIO METER RANGE 111.1	1 No						
2	MEGGAR 1000 VOLTS	1 No						
3	H.V. TRANSFORMER 0-50 KV	1 No						
4	L.V. TRANSFORMER 0-3 KV	1 No						
5	OIL TESTING SET	1 No						
6	DOUBLE VOLTAGE GENERATOR 100 CYCLE 250 500, 1000 V	1 No						
7	STOP WATCH	1 No						
8	CLIP ON METER	1 No						
9	PANEL METERS OF TEST BENCH	1 No						
10	POWER ANALYZER (with panel)	1 No.						

NOTE – ALL THE TESTING INSTRUMENTS SHALL BE CALIBRATED ONCE IN A YEAR IN GOVERNMENT/NABL APPROVED LABORATORY. CALIBRATION CERTIFICATE SHOULD BE MADE AVAILABLE TO INSPECTOR WHENEVER ASKED FOR DURING TESTING / INSPECTION.

All testing equipment's should be 0.5 class accuracy or better.

Power analyzer should be provided 0.5 class accuracy or better, duly calibrated at third party Government/NABL approved laboratory within 12 months.